



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-01	Sample Name: 0142MRHSLAUFA20001		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/25/20 15:56
0055006-02	Sample Name: 0142MRHSTRAFA20002		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-03	Sample Name: 0142MRHSBLRFA20003		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-04	Sample Name: 0142MRHSBLRFA20004		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-05	Sample Name: 0142MRHSBLRFA20006 (dup)		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-06	Sample Name: 0142MRHSBLRFA20006		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-07	Sample Name: 0142MRHSBLRFO20007		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-08	Sample Name: 0142MRHSMPRFO20008		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-09	Sample Name: 0142MRHSGYMFO20009		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-10	Sample Name: 0142MRHSGYMFO20010		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N
T Phone: (503) 680-6398

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-11	Sample Name: 0142MRHSLROFA20011		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-12	Sample Name: 0142MRHSGBRFA20012		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-13	Sample Name: 0142MRHSGBRFA20013		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-14	Sample Name: 0142MRHSGBRFA20014		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-15	Sample Name: 0142MRHSGBRFA20015		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/25/20 15:56
0055006-16	Sample Name: 0142MRHSGBRFA20016		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	02/25/20 15:56
0055006-17	Sample Name: 0142MRHSSNKFA20017		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-18	Sample Name: 0142MRHSGGRFA20018		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-19	Sample Name: 0142MRHSGGRFA20019		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-20	Sample Name: 0142MRHSGGRFA20020		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-21	Sample Name: 0142MRHSGGRFA20021		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-22	Sample Name: 0142MRHSGGRFA20022		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-23	Sample Name: 0142MRHSSWFFO20023		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-24	Sample Name: 0142MRHSGLRFO20024		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-25	Sample Name: 0142MRHSGLRFA20025		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-26	Sample Name: 0142MRHSGLRFA20027 (dup)		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-27	Sample Name: 0142MRHSGLRFA20027		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-28	Sample Name: 0142MRHSGLRFA20028		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-29	Sample Name: 0142MRHSLROFA20029		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	02/25/20 15:56
0055006-30	Sample Name: 0142MRHSBNDFO20030		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-31	Sample Name: 0142MRHSBGRFA20031 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-32	Sample Name: 0142MRHSBGRFA20032 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-33	Sample Name: 0142MRHSBWFFO20033 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-34	Sample Name: 0142MRHSBBRFA20034 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-35	Sample Name: 0142MRHSBBRFA20035 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-36	Sample Name: 0142MRHSBBRFA20036 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-37	Sample Name: 0142MRHS1CFA20037 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	02/25/20 15:56
0055006-38	Sample Name: 0142MRHS3CFA20038 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	10	ppb	2	20 ppb	02/25/20 15:56
0055006-39	Sample Name: 0142MRHS6LFA20039 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-40	Sample Name: 0142MRHS6LFA20040 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	10	ppb	2	20 ppb	02/25/20 15:56



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-41	Sample Name: 0142MRHS6CFA20041		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-42	Sample Name: 0142MRHS6CFA20042		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	02/25/20 15:56
0055006-43	Sample Name: 0142MRHS6CFA20043		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	6	ppb	2	20 ppb	02/25/20 15:56
0055006-44	Sample Name: 0142MRHS6CFA20044		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-45	Sample Name: 0142MRHS6CFA20045		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-46	Sample Name: 0142MRHS7CFA20046		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-47	Sample Name: 0142MRHS7CFA20047		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-48	Sample Name: 0142MRHS7CFA20048		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-49	Sample Name: 0142MRHS7CFA20049		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	6	ppb	2	20 ppb	02/28/20 15:40
0055006-50	Sample Name: 0142MRHS7CFA20050		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	6	ppb	2	20 ppb	02/25/20 15:56



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N
T Phone: (503) 680-6398

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-51	Sample Name: 0142MRHS7CFA20051 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-52	Sample Name: 0142MRHS7CFA20052 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-53	Sample Name: 0142MRHS8CFA20053 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-54	Sample Name: 0142MRHS8CFA20054 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-55	Sample Name: 0142MRHS8CFA20055 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	11	ppb	2	20 ppb	02/25/20 15:56
0055006-56	Sample Name: 0142MRHS8CFA20056 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	02/25/20 15:56
0055006-57	Sample Name: 0142MRHS8CFA20057 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-58	Sample Name: 0142MRHS8CFA20058 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-59	Sample Name: 0142MRHS8CFA20059 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-60	Sample Name: 0142MRHS4CFA20060 Sampled: 2/17/20 14:00		Sample Composition: Raw Single		Matrix: Drinking Water		
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N
T Phone: (503) 680-6398

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-61	Sample Name: 0142MRHSCLSA20061		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	11	ppb	2	20 ppb	02/25/20 15:56
0055006-62	Sample Name: 0142MRHS2CFA20062		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	02/25/20 15:56
0055006-63	Sample Name: 0142MRHS2CFA20063		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-64	Sample Name: 0142MRHS2CFA20064		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/25/20 15:56
0055006-65	Sample Name: 0142MRHS2CFA20065		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/25/20 15:56
0055006-66	Sample Name: 0142MRHS2CFA20066		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/25/20 15:56
0055006-67	Sample Name: 0142MRHS2CFA20067		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-68	Sample Name: 0142MRHSHLTA20068		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	02/25/20 15:56
0055006-69	Sample Name: 0142MRHSHBRFA20069		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	12	ppb	2	20 ppb	02/25/20 15:56
0055006-70	Sample Name: 0142MRHSOFFFA20070		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/25/20 15:56



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N
T Phone: (503) 680-6398

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-71	Sample Name: 0142MRHSOBRFA20071		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-72	Sample Name: 0142MRHSOBRFA20072		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-73	Sample Name: 0142MRHSFACFA20073		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	02/25/20 15:56
0055006-74	Sample Name: 0142MRHS1EFA20074		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	6	ppb	2	20 ppb	02/25/20 15:56
0055006-75	Sample Name: 0142MRHS1EFA20075		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-76	Sample Name: 0142MRHS1EFA20076		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-77	Sample Name: 0142MRHS1EFA20077		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-78	Sample Name: 0142MRHS1EFA20078		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-79	Sample Name: 0142MRHS1EFA20079		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-80	Sample Name: 0142MRHS1EFA20080		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N
T Phone: (503) 680-6398

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-81	Sample Name: 0142MRHS1EFA20081		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/25/20 15:56
0055006-82	Sample Name: 0142MRHS3EFA20082		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-83	Sample Name: 0142MRHSASTFA20083		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	9	ppb	2	20 ppb	02/26/20 16:06
0055006-84	Sample Name: 0142MRHS8EFA20084		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-85	Sample Name: 0142MRHS8EFA20085		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-86	Sample Name: 0142MRHS8EFA20086		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-87	Sample Name: 0142MRHSAWFFO20087		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-88	Sample Name: 0142MRHSABRFA20088		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-89	Sample Name: 0142MRHSABRFA20089		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-90	Sample Name: 0142MRHSABRFA20089 dup		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055006

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type :
PO # : 2020014

Sampling Location: Molalla High School, 357 Francis St, Molalla OR 9703

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055006-91	Sample Name: 0142MRHSAGRFA20091		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-92	Sample Name: 0142MRHSAGRFA20092		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-93	Sample Name: 0142MRHSAGRFA20093		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-94	Sample Name: 0142MRHSBDRFA20094		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-95	Sample Name: 0142MRHSBDRFA20095		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-96	Sample Name: 0142MRHSGDRFA20096		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-97	Sample Name: 0142MRHSGDRFA20097		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055006-98	Sample Name: 0142MRHSMTLFA20098		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40
0055006-99	Sample Name: 0142MRHSWDSFA20099		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.




**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: M
Project #: 20
Sample Type: G
PO #: 20

Sampling Location: M



Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-01							
	Sample Name: 0142MRHS WWF FO20 100						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-02							
	Sample Name: 0142MRHS WBR FA20 101						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-03							
	Sample Name: 0142MRHS WBR FA20 102						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-04							
	Sample Name: 0142MRHS WGR FA20 103						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-05							
	Sample Name: 0142MRHS WGR FA20 104						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-06							
	Sample Name: 0142MRHS WGR FA20 105						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-07							
	Sample Name: 0142MRHS KOF FA20 106						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-08							
	Sample Name: 0142MRHS KOF FA20 106 (dup)						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-09							
	Sample Name: 0142MRHS KTC FA20 107						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-10							
	Sample Name: 0142MRHS KTC FA20 108						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	6	ppb	2	20 ppb	02/26/20 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055016

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type : Grab
PO # : 2020014

Sampling Location: Molalla High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-11	Sample Name: 0142MRHS KTC FA20 109		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
†Lead							
0055016-12	Sample Name: 0142MRHS KTC FA20 110		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	2	ppb	2	20 ppb	02/26/20 16:06
†Lead							
0055016-13	Sample Name: 0142MRHS KTC FA20 111		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	5	ppb	2	20 ppb	02/26/20 16:06
†Lead							
0055016-14	Sample Name: 0142MRHS KTC FA20 112		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	19	ppb	2	20 ppb	02/26/20 16:06
†Lead							
0055016-15	Sample Name: 0142MRHS KTC FA20 113		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	87	ppb	8	20 ppb	02/26/20 16:06 MCL
†Lead							
0055016-16	Sample Name: 0142MRHS KTC FA20 114		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	4	ppb	2	20 ppb	02/26/20 16:06
†Lead							
0055016-17	Sample Name: 0142MRHS KTC FA20 115		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	1700	ppb	100	20 ppb	02/28/20 15:40 MCL
†Lead							
0055016-18	Sample Name: 0142MRHS KTC FA20 116		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	18	ppb	2	20 ppb	02/28/20 15:40
†Lead							
0055016-19	Sample Name: 0142MRHS KTC FA20 117		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	2	ppb	2	20 ppb	02/26/20 16:06
†Lead							
0055016-20	Sample Name: 0142MRHS KTC FA20 118		Sample Composition: Raw Single		Matrix: Drinking Water		
	1030	EPA 200.9	6	ppb	2	20 ppb	02/26/20 16:06
†Lead							



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055016

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type : Grab
PO # : 2020014

Sampling Location: Molalla High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-21	Sample Name: 0142MRHS KLR FA20 119		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-22	Sample Name: 0142MRHS KLR FA20 120		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-23	Sample Name: 0142MRHS KLR FA20 121		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-24	Sample Name: 0142MRHS CMM FO20 122		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-25	Sample Name: 0142MRHS CBR FA20 123		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-26	Sample Name: 0142MRHS CBR FA20 124		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-27	Sample Name: 0142MRHS CGR FA20 125		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-28	Sample Name: 0142MRHS CGR FA20 126		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-29	Sample Name: 0142MRHS 1 FA20 127		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	02/26/20 16:06
0055016-30	Sample Name: 0142MRHS 1BR FA20 128		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055016

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project #: 2020014
Sample Type: Grab
PO #: 2020014

Sampling Location: Molalla High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-31	Sample Name: 0142MRHS 2 FA20 129		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/26/20 16:06
0055016-32	Sample Name: 0142MRHS 3 FA20 130		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	02/26/20 16:06
0055016-33	Sample Name: 0142MRHS LIB FA20 131		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/26/20 16:06
0055016-34	Sample Name: 0142MRHS 1GR FA20 132		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-35	Sample Name: 0142MRHS 1GR FA20 133		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-36	Sample Name: 0142MRHS 1GR FA20 135		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-37	Sample Name: 0142MRHS 1GR FA20 135 (dup)		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-38	Sample Name: 0142MRHS 1BR FA20 136		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-39	Sample Name: 0142MRHS 1BR FA20 137		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-40	Sample Name: 0142MRHS 1BR FA20 138		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055016

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type : Grab
PO # : 2020014

Sampling Location: Molalla High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-41	Sample Name: 0142MRHS 1BR FA20 139		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-42	Sample Name: 0142MRHS COW FO20 140		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-43	Sample Name: 0142MRHS COW FO20 140 (dup)		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-44	Sample Name: 0142MRHS CSL FA20 141		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-45	Sample Name: 0142MRHS CSL FA20 142		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-46	Sample Name: 0142MRHS CSL FA20 143		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-47	Sample Name: 0142MRHS CSL FA20 144		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-48	Sample Name: 0142MRHS 2GR FA20 145		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-49	Sample Name: 0142MRHS 2GR FA20 146		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-50	Sample Name: 0142MRHS 2GR FA20 147		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055016

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N
T Phone: (503) 680-6398

Project: Molalla HS
Project # : 2020014
Sample Type : Grab
PO # : 2020014

Sampling Location: Molalla High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-51	Sample Name: 0142MRHS 2BR FA20 148		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-52	Sample Name: 0142MRHS 2BR FA20 149		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-53	Sample Name: 0142MRHS 2BR FA20 150		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-54	Sample Name: 0142MRHS 2RW FO20 151		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-55	Sample Name: 0142MRHS 10W FO20 152		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-56	Sample Name: 0142MRHS 10W FO20 153		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-57	Sample Name: 0142MRHS 10F FA20 154		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-58	Sample Name: 0142MRHS 10F FA20 155		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-59	Sample Name: 0142MRHS 10F FA20 156		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-60	Sample Name: 0142MRHS 10F FA20 157		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	02/26/20 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055016

C Environmental Inspect svc
L
I Attn: Charles Spear
E 11981 Fargo Rd
N Aurora OR, 97002
T Phone: (503) 680-6398

Project: Molalla HS
Project #: 2020014
Sample Type: Grab
PO #: 2020014

Sampling Location: Molalla High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-61	Sample Name: 0142MRHS 3BR FA20 158		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-62	Sample Name: 0142MRHS 3BR FA20 159		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-63	Sample Name: 0142MRHS 3BR FA20 160		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-64	Sample Name: 0142MRHS 3BR FA20 161		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-65	Sample Name: 0142MRHS 3GR FA20 162		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-66	Sample Name: 0142MRHS 3GR FA20 163		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-67	Sample Name: 0142MRHS 3GR FA20 164		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-68	Sample Name: 0142MRHS 3GR FA20 165		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-69	Sample Name: 0142MRHS 20F FA20 166		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/26/20 16:06
0055016-70	Sample Name: 0142MRHS 20F FA20 167		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00 Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055016

C Environmental Inspect svc

L Attn: Charles Spear

I 11981 Fargo Rd

E Aurora OR, 97002

N Phone: (503) 680-6398

T

Project: Molalla HS

Project # : 2020014

Sample Type : Grab

PO # : 2020014

Sampling Location: Molalla High School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-71	Sample Name: 0142MRHS 20F FA20 168		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-72	Sample Name: 0142MRHS 4GR FA20 169		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-73	Sample Name: 0142MRHS 4GR FA20 170		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-74	Sample Name: 0142MRHS 4GR FA20 171		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/26/20 16:06
0055016-75	Sample Name: 0142MRHS 4BR FA20 172		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40
0055016-76	Sample Name: 0142MRHS 4BR FA20 173		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40
0055016-77	Sample Name: 0142MRHS 4BR FA20 174		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40
0055016-78	Sample Name: 0142MRHS 4RW FA20 175		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40
0055016-79	Sample Name: 0142MRHS 4RW FO20 176		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40
0055016-80	Sample Name: 0142MRHS 30F FA20 177		Matrix: Drinking Water				
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/05/2020
Received: 02/24/2020
Sampled By: Charles Spear
Work Order: 0055016

C Environmental Inspect svc
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Molalla HS
Project # : 2020014
Sample Type : Grab
PO # : 2020014

Sampling Location: Molalla High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0055016-81	Sample Name: 0142MRHS 30F FA20 178						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40
0055016-82	Sample Name: 0142MRHS 30F FA20 179						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	02/28/20 15:40
0055016-83	Sample Name: 0142MRHS 30F FA20 180						Matrix: Drinking Water
	Sampled: 2/17/20 14:00		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	02/28/20 15:40

MCL This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director