



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/29/2021
Received: 11/16/2021
Sampled By:
Work Order: 1321026

C **Molalla River School District**
L Attn: Tony Tiano
I 412 S Sweigle Ave
E Molalla OR, 97038
N Phone: (503) 915-5248
T

Project: Heckard Field
Project # : -
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1321026-01	Sample Name: Boys Locker Room R Sampled: 11/15/21 14:35		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	10	ppb	2	15 ppb	11/22/21 15:29
1321026-02	Sample Name: Boys Locker Room L Sampled: 11/15/21 14:35		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	7	ppb	2	15 ppb	11/22/21 15:29
1321026-03	Sample Name: Girls Locker Room R Sampled: 11/15/21 14:37		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
1321026-04	Sample Name: Girls Locker Room L Sampled: 11/15/21 14:37		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	11/22/21 15:29
1321026-05	Sample Name: BB Concession Sampled: 11/15/21 14:59		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	3	ppb	2	15 ppb	11/22/21 15:29
1321026-06	Sample Name: FB Concession Sampled: 11/15/21 14:41		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	3	ppb	2	15 ppb	11/22/21 15:29
1321026-07	Sample Name: Heckard Training Rm. Sampled: 11/15/21 14:39		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2	ppb	2	15 ppb	11/22/21 15:29
1321026-08	Sample Name: Boys LR Public L Sampled: 11/15/21 14:29		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	20	ppb	2	15 ppb	11/22/21 15:29 MCLE
1321026-09	Sample Name: Boys LR Public M Sampled: 11/15/21 14:29		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	5	ppb	2	15 ppb	11/22/21 15:29
1321026-10	Sample Name: Boys LR Public R Sampled: 11/15/21 14:29		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	10	ppb	2	15 ppb	11/22/21 15:29



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/29/2021
Received: 11/16/2021
Sampled By:
Work Order: 1321026

CLIENT
Molalla River School District
Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project: Heckard Field
Project #: -
Sample Type:

Sampling Location:

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL*, Analysis Date/ Time. Contains three rows of data for samples 1321026-11, 1321026-12, and 1321026-13.

MCLC This analyte exceeds the MCL limit.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by:

Handwritten signature of Adriana Gonzalez-Gray

Adriana Gonzalez-Gray
Laboratory Director