



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/07/2022
Received: 06/21/2022
Sampled By: Tony Tiano
Work Order: 2172044

C
L
I
E
N
T
Molalla River School District
Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248


Project:
Project # : N/A
PWSID # : 4190529

Sampling Location: Rural Dell Elementary Sch

Lab Number

Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
2172044-01 Sample Name: Room 1 Matrix: Drinking Water Sampled: 6/16/22 14:17						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	ND	0.050	1.3	07/01/22 11:45
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	06/28/22 13:59
2172044-02 Sample Name: Room 3 Matrix: Drinking Water Sampled: 6/16/22 14:19						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	ND	0.050	1.3	07/01/22 11:45
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	06/28/22 13:59
2172044-03 Sample Name: Room 5 Matrix: Drinking Water Sampled: 6/16/22 14:20						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	ND	0.050	1.3	07/01/22 11:45
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	06/28/22 13:59
2172044-04 Sample Name: Room 7 Matrix: Drinking Water Sampled: 6/16/22 14:22						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	0.069	0.050	1.3	07/01/22 11:45
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	06/28/22 13:59
2172044-05 Sample Name: Room 9 Matrix: Drinking Water Sampled: 6/16/22 14:23						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	ND	0.050	1.3	07/01/22 11:45
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	06/28/22 13:59

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director