

**From: Tony Tiano, Facilities Supervisor**

**Re: Radon Testing Update**

This is an update for you on the initial radon testing performed in the Molalla River School District. We began testing for elevated radon levels in March during the Spring Break; Environmental Inspection Services was hired to help conduct monitoring and mitigation procedures.

Radon testing devices were placed in 434 frequently occupied rooms. Of those rooms, 6 tested above the EPA recommended action level of 4.0 picocuries per liter (pCi/L). Molalla River School District's response to elevated radon results has been prompt and comprehensive. The rooms that tested at or above 4.0 pCi/L are subject to longer confirmation testing and temporary mitigation systems. All testing results can be found at <http://www.molallariv.k12.or.us/>.

With the results of 4.0 pCi/L to 8.0 pCi/L, there will be follow-up measurement of those rooms using a long-term test. This test should be conducted over as much of a nine-month school year as possible, when the room is likely to be occupied. If that result is equal to or greater than 4.0 pCi/L, the radon in the room should be fixed (i.e., lowered).

- **Mulino Elementary-26660 OR-213, Mulino, OR 97042**
  - Classroom #22 - (5.3 pCi/L)
- **Mulino Elementary-26660 OR-213, Mulino, OR 97042**
  - Classroom #21 (8.6 pCi/L)
- **Rural Dell-211 Molalla, OR 97038**
  - Office (Mrs. Javier's) - (5.3 pCi/L)
- **Clarkes Elementary-19100 S Windy City Rd, Mulino, OR 97042**
  - Office Rm #12 - (4.5 pCi/L)
- **Clarkes Elementary-19100 S Windy City Rd, Mulino, OR 97042**
  - Office Main area - (4.0 pCi/L)
- **Clarkes Elementary-19100 S Windy City Rd, Mulino, OR 97042**
  - Office Health Room - (4.2 pCi/L)

The elevated radon measurements prompted a radon retest of the selected aforementioned school measurement areas in June, 2018. Two passive samplers were placed into each of the designated retest areas for quality control purposes resulting in a total of twelve samplers placed during the June retest. The elevated radon levels exceeded the action limit of 4 pCi/L analytically confirmed in the June samplers are listed as follows:

- **Mulino Elementary-26660 OR-213, Mulino, OR 97042**
  - Classroom #22 - (7.9 pCi/L)
- **Mulino Elementary-26660 OR-213, Mulino, OR 97042**
  - Classroom #22 (14.4 pCi/L)

- **Rural Dell-211 Molalla, OR 97038**
  - Office (Mrs. Javier's) - (6.3 pCi/L)
- **Rural Dell-211 Molalla, OR 97038**
  - Office (Mrs. Javier's) - (5.5 pCi/L)
- **Clarkes Elementary-19100 S Windy City Rd, Mulino, OR 97042**
  - Office Rm #12 - (4.5 pCi/L)
- **Clarkes Elementary-19100 S Windy City Rd, Mulino, OR 97042**
  - Office Main area - (5.3 pCi/L)
- **Clarkes Elementary-19100 S Windy City Rd, Mulino, OR 97042**
  - Office Health Room - (5 pCi/L)
- **Clarkes Elementary-19100 S Windy City Rd, Mulino, OR 97042**
  - Office Rm #12 - (4.8 pCi/L)

With the findings of these results we will now start long-term testing over a 90 day period. It is recommended that the school adjust the building's HVAC system and conduct long term retests during the summer break in the three elevated retest areas of Mulino Elementary School, the Rural Dell Elementary School, and the Clarkes Elementary School. Environmental Inspection Services recommends the application of long term testing in the elevated three diverse radon areas. The continued analytical verification of elevated monitoring procedures would prompt an EIS recommendation for radon mitigation methods.

Radon is a naturally occurring radioactive gas that you cannot see, smell or taste. It is the number-one cause of lung cancer among non-smokers, according to the Environmental Protection Agency (EPA). Elevated radon can be found across the country and in all different types of buildings, including homes and schools.

Breathing air with radon gas does not cause any immediate health effects, and not everyone exposed to elevated levels will develop lung cancer. Lung cancer usually occurs many years after exposure. Individuals who are exposed to high radon levels over long periods of time are the most at risk. Because students and staff of school buildings spend much of their time at home, the home may be their most significant source of radon exposure. The EPA recommends that all homes and schools be tested for radon.

If you have any questions or concerns about radon testing at the Molalla River School District, please feel free to contact Tony Tiano at 503-759-7487 or [tony.tiano@molallariv.k12.or.us](mailto:tony.tiano@molallariv.k12.or.us).

Thank you

**DISTRICT RADON REPORT**  
**IN ACCORDANCE TO ORS 332.166-167**

**PREPARED FOR:**  
**THE MOLALLA RIVER SCHOOL DISTRICT**  
**412 S SWIEGLE AVE**  
**MOLALLA, OR 97038**

**MOLLALA HIGH SCHOOL**  
**357 E Francis St**  
**Molalla, OR 97038**

**MOLALLA ELEMENTARY**  
**910 Toliver Rd**  
**Molalla, OR 97038**

**MULINO ELEMENTARY**  
**26660 OR-213**  
**Mulino, OR 97042**

**CLARKES ELEMENTARY**  
**19100 S Windy City Rd**  
**Mulino, OR 97042**


**RUAL DELL**  
**10500 OR-211**  
**Molalla, OR 97038**

**MOLALLA RIVER MIDDLE  
SCHOOL**  
**318 Leroy Ave**  
**Molalla, OR 97038**



**ADMINISTRATIVE OFFICES  
&  
NATURAL RESOURCE**  
**412 S Swiegle Ave**  
**Molalla, OR 97038**





April 26<sup>rd</sup> 2018

Tony Mann - Superintendent  
Tony Tiano - Facilities Supervisor  
Molalla River School District  
412 S Swiegle Ave  
Molalla, Oregon 97038  
Via email: [tony.mann@molallariv.k12](mailto:tony.mann@molallariv.k12)  
[tony.tiano@molalaariv.k12](mailto:tony.tiano@molalaariv.k12)

Regarding: District-Wide Radon Testing  
Molalla River School District  
412 S Swiegle Ave  
Molalla, Oregon 97038  
EIS Project 201819

Dear Mr. Mann & Mr. Tiano:

From March 26th to March 29th, 2018, Environmental Inspection Services (EIS) performed short-term radon testing at the Molalla River School District buildings located at:

- **MOLLALA HIGH SCHOOL- 357 E Francis St, Molalla, OR 97038**
- **MOLALLA ELEMENTARY- 910 Toliver Rd, Molalla, OR 97038**
- **MULINO ELEMENTARY- 26660 OR-213, Mulino, OR 97042**
- **ADMINISTRATIVE OFFICES & NATURAL RESOURCE- 412 S Swiegle Ave, Molalla, OR 97038**
- **CLARKES ELEMENTARY- 19100 S Windy City Rd, Mulino, OR 97042**
- **RUAL DELL- 10500 OR-211, Molalla, OR 97038**
- **MOLALLA RIVER MIDDLE SCHOOL- 318 Leroy Ave, Molalla, OR 97038**


The Environmental Protection Agency (EPA) and Oregon Health Authority (OHA) recommend that buildings be tested for radon and that any radon concentrations be maintained below 4.0 picocuries per liter (pCi/L) of air. EIS used Pro-Lab brand single-use, short-term radon test kits to measure radon levels in frequently-occupied rooms that are in contact with the ground or above unoccupied basements or crawlspaces.

**Laboratory results indicate that all short-term radon tests at the following locations were below 4.0 pCi/L.**

- **MOLLALA HIGH SCHOOL- 357 E Francis St, Molalla, OR 97038**
- **MOLALLA ELEMENTARY- 910 Toliver Rd, Molalla, OR 97038**
- **MOLALLA RIVER MIDDLE SCHOOL- 318 Leroy Ave, Molalla, OR 97038**
- **ADMINISTRATIVE OFFICES & NATURAL RESOURCE- 412 S Swiegle Ave, Molalla, OR 97038**

\*See the attached laboratory analysis report for more details.





In addition to the EPA recommendation that radon concentrations not exceed 4.0 pCi/L, OHA recommends that the following steps be conducted based on the results of a room's initial short-term test:

**If the result is less than 2.0 pCi/L**, school districts are required to test again every 10 years, per Oregon Revised Statute 332.166-167.

**If the result is between 2.0 pCi/L and 4.0 pCi/L**, consider fixing (i.e., lowering) the radon in that room.

\*See the attached laboratory analysis report for more details.

**If the result is from 4.0 pCi/L to 8.0 pCi/L**, perform a follow-up measurement of that room using a long-term test. This test should be conducted over as much of a nine-month school year as possible, when the room is likely to be occupied. If that result is equal to or greater than 4.0 pCi/L, the radon in the room should be fixed (i.e., lowered).

**The following locations were between 4.0 pCi/L to 8.0 pCi/L.**

- **MULINO ELEMENTARY- 26660 OR-213, Mulino, OR 97042**
  - CLASSROOM #22 VILE# 4453097 (5.3 pCi/L0)
- **RUAL DELL- 10500 OR-211, Molalla, OR 97038**
  - OFFICE (MRS. JAVIER'S) Vile# 4453097 (5.3 pCi/L0)
- **CLARKES ELEMENTARY- 19100 S Windy City Rd, Mulino, OR 97042**
  - OFFICE (ROOM #12) Vile# 4525772 (4.5 pCi/L0)
- **CLARKES ELEMENTARY- 19100 S Windy City Rd, Mulino, OR 97042**
  - OFFICE (MAIN OFFICE AREA NEAR #12) Vile# 4525972 (4.0 pCi/L0)
- **CLARKES ELEMENTARY- 19100 S Windy City Rd, Mulino, OR 97042**
  - OFFICE (MAIN OFFICE AREA- HEALTH ROOM) Vile# 4525708 (4.2 pCi/L)

\*See the attached laboratory analysis report for more details.

**If the initial short-term test result is equal to or greater than 8.0 pCi/L**, conduct a second short-term test and average its result with the initial short-term test result. If the average of the two is equal to or greater than 4.0 pCi/L, radon in the room should be fixed (i.e., lowered).

**The following locations were equal to or greater than 8.0 pCi/L.**

- **MULINO ELEMENTARY- 26660 OR-213, Mulino, OR 97042**
  - CLASSROOM #21 VILE# 4607923 (8.6 pCi/L0)

\*See the attached laboratory analysis report for more details.







**LAB ANALYSIS FOR:**

**CLARKES ELEMENTARY  
19100 S Windy City Rd  
Mulino, OR 97042**



**TEST ID NUMBER:** 1163069  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525962	2ND FLOOR GYM	Mar 27, 2018 12:10 PM	Mar 29, 2018 4:25 PM	Apr 07, 2018 12:45 PM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163071  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453239	2ND FLOOR GYM	Mar 27, 2018 12:12 PM	Mar 29, 2018 4:30 PM	Apr 07, 2018 12:34 PM	1.0 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163074  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453277	BASEMENT GYM	Mar 27, 2018 12:14 PM	Mar 29, 2018 4:30 PM	Apr 07, 2018 12:23 PM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163077  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525833	2ND FLOOR GYM	Mar 27, 2018 12:15 PM	Mar 29, 2018 4:32 PM	Apr 07, 2018 12:13 PM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163082  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525997	2ND FLOOR GYM	Mar 27, 2018 12:17 PM	Mar 29, 2018 4:33 PM	Apr 07, 2018 12:02 PM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163089  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453270	2ND FLOOR GYM	Mar 27, 2018 12:10 PM	Mar 29, 2018 4:43 PM	Apr 07, 2018 11:51 AM	2.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163091  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453281	2ND FLOOR OTHER	Mar 27, 2018 12:15 PM	Mar 29, 2018 4:28 PM	Apr 07, 2018 5:56 AM	1.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163092  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607993	2ND FLOOR OFFICE	Mar 27, 2018 12:15 PM	Mar 29, 2018 4:28 PM	Apr 07, 2018 5:45 AM	1.7 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



TEST ID NUMBER: 1163094  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453112	2ND FLOOR OTHER	Mar 27, 2018 12:15 PM	Mar 29, 2018 4:28 PM	Apr 07, 2018 2:57 PM	2.0 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163096  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525819	2ND FLOOR OFFICE	Mar 27, 2018 12:00 PM	Mar 29, 2018 4:40 PM	Apr 07, 2018 2:47 PM	1.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163098  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337171	2ND FLOOR OFFICE	Mar 27, 2018 12:05 PM	Mar 29, 2018 4:40 PM	Apr 07, 2018 2:37 PM	1.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163101  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607967	2ND FLOOR GYM	Mar 27, 2018 12:05 PM	Mar 29, 2018 4:42 PM	Apr 07, 2018 2:27 PM	1.1 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163104  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97002

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525978	2ND FLOOR GYM	Mar 27, 2018 12:10 PM	Mar 29, 2018 4:42 PM	Apr 07, 2018 2:17 PM	2.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163109  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525811	2ND FLOOR OFFICE	Mar 27, 2018 12:05 PM	Mar 29, 2018 4:55 PM	Apr 07, 2018 2:07 PM	1.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163115  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533388	2ND FLOOR OFFICE	Mar 27, 2018 12:05 PM	Mar 29, 2018 4:55 PM	Apr 07, 2018 3:58 AM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163117  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453327	2ND FLOOR OFFICE	Mar 27, 2018 12:06 PM	Mar 29, 2018 4:55 PM	Apr 07, 2018 5:47 AM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163122  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97002

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525686	2ND FLOOR OFFICE	Mar 27, 2018 12:08 PM	Mar 29, 2018 4:58 PM	Apr 07, 2018 5:36 AM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163128  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607982	2ND FLOOR OFFICE	Mar 27, 2018 12:10 PM	Mar 29, 2018 4:55 PM	Apr 07, 2018 1:49 PM	1.1 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163133  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453265	2ND FLOOR OFFICE	Mar 27, 2018 12:11 PM	Mar 29, 2018 4:55 PM	Apr 07, 2018 1:39 PM	1.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163136  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337185	2ND FLOOR GYM	Mar 27, 2018 12:16 PM	Mar 29, 2018 4:35 PM	Apr 07, 2018 3:27 PM	1.0 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163142  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97002

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453233	2ND FLOOR GYM	Mar 27, 2018 12:17 PM	Mar 29, 2018 4:36 PM	Apr 07, 2018 3:17 PM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163056  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525772	2ND FLOOR OFFICE	Mar 27, 2018 11:57 AM	Mar 29, 2018 4:25 PM	Apr 07, 2018 1:28 PM	4.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163062  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525972	2ND FLOOR OFFICE	Mar 27, 2018 11:59 AM	Mar 29, 2018 4:20 PM	Apr 07, 2018 1:17 PM	4.0 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163066  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

CLARKES ELEMENTARY  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525708	BASEMENT HEALTH ROOM	Mar 27, 2018 12:00 PM	Mar 29, 2018 4:21 PM	Apr 07, 2018 12:56 PM	4.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**LAB ANALYSIS FOR:**

**ADMINISTRATIVE OFFICES**

**&**

**NATURAL RESOURCE**

**412 S Swiegle Ave**

**Molalla, OR 97038**



**TEST ID NUMBER:** 1163028  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525683	2ND FLOOR OFFICE	Mar 27, 2018 11:00 AM	Mar 29, 2018 3:35 PM	Apr 07, 2018 1:39 AM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163029  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525844	2ND FLOOR OFFICE	Mar 27, 2018 11:00 AM	Mar 29, 2018 3:15 PM	Apr 07, 2018 1:29 AM	1.0 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163030  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525754	2ND FLOOR OFFICE	Mar 27, 2018 11:05 AM	Mar 29, 2018 3:12 PM	Apr 07, 2018 1:18 AM	0.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163031  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533394	2ND FLOOR OFFICE	Mar 27, 2018 11:10 AM	Mar 29, 2018 3:11 PM	Apr 07, 2018 1:07 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163032  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525806	2ND FLOOR OFFICE	Mar 27, 2018 11:08 AM	Mar 29, 2018 3:15 PM	Apr 07, 2018 12:56 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163033  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453258	2ND FLOOR OFFICE	Mar 27, 2018 11:09 AM	Mar 29, 2018 3:15 PM	Apr 07, 2018 12:46 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163034  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453245	BASEMENT OFFICE	Mar 27, 2018 11:00 AM	Mar 29, 2018 3:25 PM	Apr 07, 2018 12:35 AM	0.8 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163035  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533392	BASEMENT OTHER	Mar 27, 2018 11:01 AM	Mar 29, 2018 3:22 PM	Apr 07, 2018 12:24 AM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163036  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525823	BASEMENT OFFICE	Mar 27, 2018 11:02 AM	Mar 29, 2018 3:22 PM	Apr 07, 2018 12:13 AM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163037  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525906	2ND FLOOR OFFICE	Mar 27, 2018 10:50 AM	Mar 29, 2018 3:35 PM	Apr 07, 2018 12:03 AM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163038  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525995	2ND FLOOR OFFICE	Mar 27, 2018 10:55 AM	Mar 29, 2018 3:10 PM	Apr 06, 2018 11:52 PM	0.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163039  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525852	2ND FLOOR OFFICE	Mar 27, 2018 10:55 AM	Mar 29, 2018 3:10 PM	Apr 06, 2018 11:41 PM	0.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163040  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607944	2ND FLOOR OFFICE	Mar 27, 2018 11:00 AM	Mar 29, 2018 3:11 PM	Apr 07, 2018 3:48 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163102  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION OFFICE  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453269	2ND FLOOR GYM	Mar 27, 2018 11:06 AM	Mar 29, 2018 3:15 PM	Apr 07, 2018 3:37 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163106  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453074	2ND FLOOR GYM	Mar 27, 2018 11:07 AM	Mar 29, 2018 3:15 PM	Apr 07, 2018 3:27 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163107  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525953	2ND FLOOR OFFICE	Mar 27, 2018 11:07 AM	Mar 29, 2018 3:15 PM	Apr 07, 2018 3:16 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163110  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525681	2ND FLOOR OFFICE	Mar 27, 2018 11:10 AM	Mar 29, 2018 3:12 PM	Apr 07, 2018 3:05 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163112  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

ADMINISTRATION BUILDING  
412 SWIEGLE AVE  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525911	2ND FLOOR OTHER	Mar 27, 2018 11:10 AM	Mar 29, 2018 3:14 PM	Apr 07, 2018 2:55 AM	0.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163179  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

NATURAL ROSARU  
NOT PROVIDED  
NOT PROVIDED  
NOT PROVIDED, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607954	2ND FLOOR OTHER	Mar 27, 2018 11:30 AM	Mar 29, 2018 4:02 PM	Apr 07, 2018 11:30 AM	0.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163182  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
NATURAL ROSARU  
NOT PROVIDED  
NO PROVIDED  
NOT PROVIDED, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533397	2ND FLOOR GYM	Mar 27, 2018 11:30 AM	Mar 29, 2018 4:02 PM	Apr 07, 2018 7:56 AM	0.7 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163184  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
NATURAL ROSARU  
NOT PROVIDED  
NOT PROVIDED  
NOT PROVIDED, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4568849	2ND FLOOR OTHER	Mar 27, 2018 11:30 AM	Mar 29, 2018 4:04 PM	Apr 07, 2018 5:00 AM	0.8 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163186  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

NATURAL ROSARU  
NOT PROVIDED  
NOT PROVIDED  
NOT PROVIDED, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525738	BASEMENT OTHER	Mar 27, 2018 11:35 AM	Mar 29, 2018 4:00 PM	Apr 07, 2018 5:11 AM	0.7 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL





**LAB ANALYSIS FOR:**

**MOLALLA ELEMENTARY  
910 Toliver Rd  
Molalla, OR 97038**



**TEST ID NUMBER:** 1163103  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525984	2ND FLOOR GYM-CLASS 16	Mar 26, 2018 12:50 PM	Mar 29, 2018 1:22 PM	Apr 07, 2018 4:20 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163123  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525678	2ND FLOOR SUPPORT	Mar 26, 2018 12:52 PM	Mar 29, 2018 1:23 PM	Apr 07, 2018 3:59 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163126  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525829	2ND FLOOR GYM-CLASS 33	Mar 26, 2018 12:52 PM	Mar 29, 2018 1:27 PM	Apr 07, 2018 4:42 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163132  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525709	2ND FLOOR GYM-CLASS 20	Mar 26, 2018 12:38 PM	Mar 29, 2018 1:13 PM	Apr 07, 2018 4:31 AM	0.3 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163135  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525743	2ND FLOOR GYM-CLASS 19	Mar 26, 2018 12:43 PM	Mar 29, 2018 1:15 PM	Apr 07, 2018 1:20 PM	0.8 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163139  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525986	2ND FLOOR GYM-CLASS 18	Mar 26, 2018 12:43 PM	Mar 29, 2018 1:15 PM	Apr 07, 2018 1:10 PM	0.6 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163140  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525826	2ND FLOOR GYM-CLASS 17	Mar 26, 2018 12:45 PM	Mar 29, 2018 1:16 PM	Apr 07, 2018 1:00 PM	0.9 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163145  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453325	2ND FLOOR OFFICE-25	Mar 27, 2018 9:02 AM	Mar 29, 2018 1:32 PM	Apr 07, 2018 4:53 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163148  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4568742	2ND FLOOR OFFICE-42	Mar 27, 2018 9:00 AM	Mar 29, 2018 1:32 PM	Apr 07, 2018 3:57 PM	0.5 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163150  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525842	2ND FLOOR OFFICE-842	Mar 27, 2018 9:04 AM	Mar 29, 2018 1:32 PM	Apr 07, 2018 5:28 AM	0.6 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163152  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453307	2ND FLOOR OFFICE-07	Mar 27, 2018 9:04 AM	Mar 29, 2018 1:32 PM	Apr 07, 2018 5:18 AM	0.4 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163156  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525961	2ND FLOOR GYM-ANNEX	Mar 27, 2018 9:12 AM	Mar 29, 2018 1:48 PM	Apr 07, 2018 5:08 AM	0.5 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163158  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525959	2ND FLOOR GYM-ANNEX CORNER OFFICE	Mar 27, 2018 9:17 AM	Mar 29, 2018 1:52 PM	Apr 07, 2018 4:58 AM	0.9 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



TEST ID NUMBER: 1163161  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525970	2ND FLOOR GYM MODULAR-MUSIC	Mar 27, 2018 9:17 AM	Mar 29, 2018 1:52 PM	Apr 07, 2018 6:15 AM	0.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163166  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607985	BASEMENT CAFETERIA	Mar 26, 2018 12:58 PM	Mar 29, 2018 1:29 PM	Apr 07, 2018 6:05 AM	0.5 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163168  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525788	BASEMENT CAFETERIA	Mar 26, 2018 12:58 PM	Mar 29, 2018 1:31 PM	Apr 07, 2018 11:40 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163118  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALL ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525900	2ND FLOOR GYM	Mar 27, 2018 9:00 AM	Mar 29, 2018 1:25 PM	Apr 07, 2018 2:44 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163121  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525902	2ND FLOOR OFFICE	Mar 27, 2018 9:05 AM	Mar 29, 2018 1:25 PM	Apr 07, 2018 2:33 AM	0.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163125  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453315	2ND FLOOR GYM	Mar 27, 2018 9:05 AM	Mar 29, 2018 1:25 PM	Apr 07, 2018 2:22 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163129  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525803	2ND FLOOR OFFICE	Mar 27, 2018 9:00 AM	Mar 29, 2018 1:25 PM	Apr 07, 2018 2:12 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163130  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337195	2ND FLOOR OTHER	Mar 27, 2018 9:15 AM	Mar 29, 2018 1:15 PM	Apr 07, 2018 2:01 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163134  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337169	2ND FLOOR OTHER	Mar 27, 2018 9:15 AM	Mar 29, 2018 1:15 PM	Apr 07, 2018 1:50 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163138  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525918	2ND FLOOR OTHER	Mar 27, 2018 9:15 AM	Mar 29, 2018 1:15 PM	Apr 07, 2018 1:50 PM	0.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163141  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525696	2ND FLOOR OFFICE	Mar 26, 2018 12:40 PM	Mar 29, 2018 1:20 PM	Apr 07, 2018 1:40 PM	0.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163144  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525838	2ND FLOOR OFFICE	Mar 26, 2018 12:45 PM	Mar 29, 2018 1:20 PM	Apr 07, 2018 1:30 PM	0.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163147  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607956	2ND FLOOR OFFICE	Mar 26, 2018 12:50 PM	Mar 29, 2018 1:20 PM	Apr 07, 2018 3:47 PM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163149  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337191	2ND FLOOR CLINICAL	Mar 26, 2018 12:51 PM	Mar 29, 2018 1:15 PM	Apr 07, 2018 3:07 PM	0.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163151  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525692	2ND FLOOR OFFICE	Mar 26, 2018 12:55 PM	Mar 29, 2018 1:15 PM	Apr 07, 2018 7:35 AM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163153  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525725	2ND FLOOR OFFICE	Mar 26, 2018 12:52 PM	Mar 29, 2018 1:15 PM	Apr 06, 2018 11:57 PM	0.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163157  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453171	2ND FLOOR OFFICE	Mar 26, 2018 1:00 PM	Mar 29, 2018 1:16 PM	Apr 07, 2018 12:08 AM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163163  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525679	BASEMENT OPEN AREA	Mar 27, 2018 9:05 AM	Mar 29, 2018 1:33 PM	Apr 07, 2018 12:18 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163167  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525795	2ND FLOOR GYM	Mar 27, 2018 9:05 AM	Mar 29, 2018 1:33 PM	Apr 07, 2018 12:29 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163171  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453292	2ND FLOOR GYM	Mar 27, 2018 9:00 AM	Mar 29, 2018 1:34 PM	Apr 07, 2018 12:40 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163174  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525827	2ND FLOOR GYM	Mar 27, 2018 9:11 AM	Mar 29, 2018 1:35 PM	Apr 07, 2018 12:50 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163178  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453143	BASEMENT OPEN KINDERGARDEN	Mar 26, 2018 12:41 PM	Mar 29, 2018 1:19 PM	Apr 07, 2018 1:01 AM	0.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163201  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525923	2ND FLOOR GYM	Mar 26, 2018 12:43 PM	Mar 29, 2018 1:19 PM	Apr 07, 2018 1:03 AM	0.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163207  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS


<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525834	2ND FLOOR GYM	Mar 26, 2018 12:44 PM	Mar 29, 2018 1:20 PM	Apr 07, 2018 1:14 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163212  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337174	2ND FLOOR GYM	Mar 26, 2018 12:45 PM	Mar 29, 2018 1:21 PM	Apr 07, 2018 1:25 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163217  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533381	2ND FLOOR OFFICE	Mar 26, 2018 12:30 PM	Mar 29, 2018 1:35 PM	Apr 07, 2018 1:35 AM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163222  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525872	2ND FLOOR GYM	Mar 26, 2018 12:35 PM	Mar 29, 2018 1:17 PM	Apr 07, 2018 1:46 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163227  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607959	2ND FLOOR GYM	Mar 26, 2018 12:35 PM	Mar 29, 2018 1:18 PM	Apr 07, 2018 1:57 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163231  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525963	2ND FLOOR GYM	Mar 26, 2018 12:38 PM	Mar 29, 2018 1:18 PM	Apr 07, 2018 2:08 AM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163237  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453323	2ND FLOOR STAFF ROOM	Mar 27, 2018 9:00 AM	Mar 29, 2018 1:26 PM	Apr 07, 2018 2:18 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163242  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525724	2ND FLOOR GYM	Mar 27, 2018 9:03 AM	Mar 29, 2018 1:30 PM	Apr 07, 2018 2:29 AM	0.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163248  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525879	2ND FLOOR GYM	Mar 27, 2018 9:04 AM	Mar 29, 2018 1:31 PM	Apr 07, 2018 3:39 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163252  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525813	2ND FLOOR GYM	Mar 27, 2018 9:05 AM	Mar 29, 2018 1:32 PM	Apr 07, 2018 3:37 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163119  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/10/2018

ENVIRONMENTAL INSPECTION SERVICES  
11981 FARGO RD  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA ELEMENTARY  
910 TOLIVAR RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525919	2ND FLOOR GYM-CLASS 15	Mar 26, 2018 12:50 PM	Mar 29, 2018 1:23 PM	Apr 07, 2018 4:10 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**LAB ANALYSIS FOR:**

**MOLLALA HIGH SCHOOL  
357 E Francis St  
Molalla, OR 97038**





**TEST ID NUMBER:** 1163053  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/11/2018

ENVIRONMENTAL INSPECTION SERVICE  
11981 FARGO ROAD  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607999	BASEMENT GIRLS LOCKER ROOM	Mar 26, 2018 8:45 AM	Mar 29, 2018 9:03 AM	Apr 07, 2018 3:18 AM	0.4 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163054  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/11/2018

ENVIRONMENTAL INSPECTION SERVICE  
11981 FARGO ROAD  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525979	1ST FLOOR ROBOTICS ROOM	Mar 26, 2018 8:50 AM	Mar 29, 2018 9:07 AM	Apr 07, 2018 12:37 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163049  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/11/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607986	BASEMENT OFFICE	Mar 26, 2018 8:39 AM	Mar 29, 2018 8:51 AM	Apr 07, 2018 2:35 AM	0.4 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163051  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/11/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453293	BASEMENT OFFICE	Mar 26, 2018 8:41 AM	Mar 29, 2018 8:50 AM	Apr 07, 2018 3:07 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163057  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/11/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607921	1ST FLOOR SCIENCE ROOM	Mar 26, 2018 8:55 AM	Mar 29, 2018 9:09 AM	Apr 07, 2018 12:48 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163059  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/11/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453288	1ST FLOOR GYM	Mar 26, 2018 8:58 AM	Mar 29, 2018 9:11 AM	Apr 07, 2018 12:59 AM	0.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163060  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/11/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607988	1ST FLOOR GYM	Mar 26, 2018 9:00 AM	Mar 29, 2018 9:12 AM	Apr 07, 2018 1:09 AM	0.4 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163064  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/11/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525765	1ST FLOOR GYM	Mar 26, 2018 9:03 AM	Mar 29, 2018 9:14 AM	Apr 07, 2018 6:28 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163080  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525690	1ST FLOOR OFFICE	Mar 26, 2018 7:26 AM	Mar 29, 2018 8:20 AM	Apr 07, 2018 7:21 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163081  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525677	1ST FLOOR ASSIT. MAIN OFFICE	Mar 26, 2018 7:27 AM	Mar 29, 2018 8:33 AM	Apr 07, 2018 7:11 PM	0.6 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163084  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525688	2ND FLOOR OFFICE	Mar 26, 2018 7:35 AM	Mar 29, 2018 8:34 AM	Apr 07, 2018 7:00 PM	0.6 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163087  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453170	BASEMENT OFFICE	Mar 26, 2018 7:36 AM	Mar 29, 2018 8:35 AM	Apr 07, 2018 8:58 PM	0.6 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163095  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525964	1ST FLOOR OFFICE	Mar 26, 2018 8:02 AM	Mar 29, 2018 8:30 AM	Apr 07, 2018 6:41 AM	0.9 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163097  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453305	1ST FLOOR OPEN AREA	Mar 26, 2018 8:05 AM	Mar 29, 2018 8:28 AM	Apr 07, 2018 6:51 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163100  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607922	BASEMENT OPEN ENTRY	Mar 26, 2018 8:06 AM	Mar 29, 2018 8:21 AM	Apr 07, 2018 8:37 PM	0.4 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163111  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525793	1ST FLOOR LOCKER ROOM 313	Mar 26, 2018 8:30 AM	Mar 29, 2018 8:59 AM	Apr 06, 2018 11:33 PM	0.3 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163116  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525722	1ST FLOOR BAND ROOM	Mar 26, 2018 8:10 AM	Mar 29, 2018 8:40 AM	Apr 07, 2018 3:28 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163120  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4568851	1ST FLOOR CHOIR ROOM	Mar 26, 2018 8:12 AM	Mar 29, 2018 8:45 AM	Apr 07, 2018 3:39 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163124  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525718	BASEMENT OFFICE	Mar 26, 2018 8:15 AM	Mar 29, 2018 8:57 AM	Apr 07, 2018 2:46 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163127  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4568653	1ST FLOOR OFFICE	Mar 26, 2018 8:16 AM	Mar 29, 2018 8:54 AM	Apr 07, 2018 2:56 AM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163131  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525809	BASEMENT OFFICE 09	Mar 26, 2018 7:45 AM	Mar 29, 2018 8:22 AM	Apr 07, 2018 2:13 AM	0.4 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163137  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525908	BASEMENT CONFERENCE ROOM	Mar 26, 2018 7:50 AM	Mar 29, 2018 8:24 AM	Apr 07, 2018 4:20 AM	0.4 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163407  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525855	2ND FLOOR ROOM 200 OFFICE	Mar 26, 2018 7:40 AM	Mar 29, 2018 8:30 AM	Apr 08, 2018 6:56 AM	0.4 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163068  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525910	1ST FLOOR BREAK ROOM	Mar 26, 2018 7:41 AM	Mar 29, 2018 8:35 AM	Apr 07, 2018 6:17 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163072  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525762	1ST FLOOR OPEN AREA	Mar 26, 2018 7:42 AM	Mar 29, 2018 8:34 AM	Apr 07, 2018 6:49 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163075  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOLL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607979	1ST FLOOR CAFETERIA ROOM	Mar 26, 2018 7:45 AM	Mar 29, 2018 8:21 AM	Apr 07, 2018 6:38 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163078  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525689	1ST FLOOR NURSE OFFICE	Mar 26, 2018 7:46 AM	Mar 29, 2018 8:22 AM	Apr 07, 2018 7:32 PM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163093  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607973	1ST FLOOR OFFICE	Mar 26, 2018 7:59 AM	Mar 29, 2018 8:28 AM	Apr 07, 2018 8:47 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163105  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453192	BASEMENT LOCKER ROOM	Mar 26, 2018 8:26 AM	Mar 29, 2018 8:58 AM	Apr 07, 2018 8:26 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163114  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453238	BASEMENT OFFICE	Mar 26, 2018 8:35 AM	Mar 29, 2018 8:53 AM	Apr 06, 2018 11:44 PM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163143  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337175	BASEMENT PHYSICS ROOM	Mar 26, 2018 7:52 AM	Mar 29, 2018 10:16 AM	Apr 07, 2018 4:09 AM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163146  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453219	1ST FLOOR REBECCA MCKENZIE	Mar 26, 2018 7:54 AM	Mar 29, 2018 10:15 AM	Apr 07, 2018 3:37 PM	1.1 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163191  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525893	1ST FLOOR LIBRARY	Mar 26, 2018 7:40 AM	Mar 29, 2018 10:05 AM	Apr 07, 2018 5:22 AM	1.0 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163193  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525822	1ST FLOOR MEDIA CLASSROOM	Mar 26, 2018 7:43 AM	Mar 29, 2018 8:26 AM	Apr 07, 2018 5:33 AM	1.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163196  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525925	1ST FLOOR CLASSROOM 2	Mar 26, 2018 7:52 AM	Mar 29, 2018 8:28 AM	Apr 07, 2018 5:43 AM	1.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



TEST ID NUMBER: 1163198  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525922	1ST FLOOR OUTREACH	Mar 26, 2018 7:49 AM	Mar 29, 2018 8:32 AM	Apr 07, 2018 5:54 AM	1.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163202  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607933	1ST FLOOR CAFETERIA	Mar 26, 2018 7:33 AM	Mar 29, 2018 9:12 AM	Apr 07, 2018 6:05 AM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163205  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525764	1ST FLOOR CAFETERIA	Mar 26, 2018 7:35 AM	Mar 29, 2018 8:15 AM	Apr 07, 2018 6:16 AM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163209  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4568830	1ST FLOOR LIBRARY COUNTER	Mar 26, 2018 7:41 AM	Mar 29, 2018 8:15 AM	Apr 07, 2018 6:26 AM	1.1 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163211  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525753	1ST FLOOR LIBRARY	Mar 26, 2018 7:42 AM	Mar 29, 2018 8:23 AM	Apr 07, 2018 6:37 AM	1.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163216  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453250	1ST FLOOR CAFETERIA - COMMON	Mar 26, 2018 7:27 AM	Mar 29, 2018 8:15 AM	Apr 07, 2018 6:48 AM	0.7 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163218  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453121	1ST FLOOR CAFETERIA	Mar 26, 2018 7:27 AM	Mar 29, 2018 8:15 AM	Apr 07, 2018 6:59 AM	0.7 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



TEST ID NUMBER: 1163220  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4568735	1ST FLOOR CAFETERIA	Mar 26, 2018 7:29 AM	Mar 29, 2018 8:15 AM	Apr 07, 2018 2:51 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163224  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97002

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525980	1ST FLOOR CAFETERIA	Mar 26, 2018 7:31 AM	Mar 29, 2018 8:15 AM	Apr 07, 2018 3:02 AM	1.1 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163229  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607976	BASEMENT AUDITORIUM SHOP	Mar 26, 2018 9:10 AM	Mar 29, 2018 10:21 AM	Apr 07, 2018 3:12 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163236  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525915	2ND FLOOR AUDITORIUM	Mar 26, 2018 9:15 AM	Mar 29, 2018 9:02 AM	Apr 07, 2018 3:34 AM	1.0 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163238  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337182	2ND FLOOR AUDITORIUM	Mar 26, 2018 9:17 AM	Mar 29, 2018 9:02 AM	Apr 07, 2018 3:45 AM	1.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163243  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525931	2ND FLOOR PHOTO ROOM	Mar 26, 2018 8:42 AM	Mar 29, 2018 8:58 AM	Apr 07, 2018 3:56 AM	0.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163246  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525930	2ND FLOOR 9E TECH LAB	Mar 26, 2018 8:48 AM	Mar 29, 2018 8:59 AM	Apr 07, 2018 4:06 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163253  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453213	2ND FLOOR METAL SHOP	Mar 26, 2018 8:58 AM	Mar 29, 2018 10:12 AM	Apr 07, 2018 4:17 AM	0.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163256  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4568894	2ND FLOOR METAL SHOP	Mar 26, 2018 9:00 AM	Mar 29, 2018 10:12 AM	Apr 07, 2018 4:28 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163259  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525808	1ST FLOOR OFFICE-6E	Mar 26, 2018 8:38 AM	Mar 29, 2018 8:52 AM	Apr 06, 2018 11:37 PM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163261  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525697	2ND FLOOR CLASSROOM-5E	Mar 26, 2018 8:38 AM	Mar 29, 2018 8:52 AM	Apr 06, 2018 11:48 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163264  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525870	2ND FLOOR CLASSROOM	Mar 26, 2018 8:45 AM	Mar 29, 2018 8:58 AM	Apr 06, 2018 11:59 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163267  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525735	2ND FLOOR ART-8E	Mar 26, 2018 8:45 AM	Mar 29, 2018 8:58 AM	Apr 07, 2018 12:10 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163269  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525999	BASEMENT WOOD SHOP OFFICE	Mar 26, 2018 8:24 AM	Mar 29, 2018 8:50 AM	Apr 07, 2018 12:21 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163273  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337180	BASEMENT WOOD SHOP	Mar 26, 2018 8:27 AM	Mar 29, 2018 8:50 AM	Apr 07, 2018 12:32 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163274  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525763	1ST FLOOR WOOD SHOP	Mar 26, 2018 8:30 AM	Mar 29, 2018 8:51 AM	Apr 07, 2018 12:43 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



TEST ID NUMBER: 1163277  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525912	BASEMENT OFFICE-4E	Mar 26, 2018 8:40 AM	Mar 29, 2018 8:45 AM	Apr 07, 2018 12:53 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163282  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525847	1ST FLOOR FACULTY LUNCH ROOM	Mar 26, 2018 8:01 AM	Mar 29, 2018 8:38 AM	Apr 07, 2018 1:04 AM	0.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163286  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525702	1ST FLOOR CUSTODIAL RECEIVING	Mar 26, 2018 8:04 AM	Mar 29, 2018 8:42 AM	Apr 07, 2018 1:15 AM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163290  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525862	1ST FLOOR ECON1	Mar 26, 2018 8:08 AM	Mar 29, 2018 8:42 AM	Apr 07, 2018 4:38 AM	0.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163295  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607939	BASEMENT AUDITORIUM-REAR CENTER	Mar 26, 2018 9:20 AM	Mar 29, 2018 9:02 AM	Apr 07, 2018 4:49 AM	0.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163324  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525749	2ND FLOOR CLASSROOM	Mar 26, 2018 8:50 AM	Mar 29, 2018 9:05 AM	Apr 07, 2018 5:37 AM	0.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163327  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525954	2ND FLOOR CLASSROOM	Mar 26, 2018 8:50 AM	Mar 29, 2018 9:05 AM	Apr 07, 2018 3:07 AM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163328  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453287	2ND FLOOR CLASSROOM 115B	Mar 26, 2018 8:55 AM	Mar 29, 2018 9:10 AM	Apr 07, 2018 2:40 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163331  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607983	2ND FLOOR CLASSROOM 1114B	Mar 26, 2018 8:55 AM	Mar 29, 2018 9:10 AM	Apr 07, 2018 3:17 AM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163335  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525710	2ND FLOOR CLASSROOM 1113B	Mar 26, 2018 9:00 AM	Mar 29, 2018 9:10 AM	Apr 07, 2018 3:28 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163338  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337192	2ND FLOOR CLASSROOM 112B	Mar 26, 2018 9:00 AM	Mar 29, 2018 9:15 AM	Apr 07, 2018 2:24 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163339  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525920	2ND FLOOR CLASSROOM 111B	Mar 26, 2018 9:05 AM	Mar 29, 2018 9:15 AM	Apr 07, 2018 2:35 AM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163341  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533384	2ND FLOOR CLASSROOM 110B	Mar 26, 2018 9:10 AM	Mar 29, 2018 9:20 AM	Apr 07, 2018 2:45 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163345  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525701	1ST FLOOR CLASSROOM 109B	Mar 26, 2018 9:20 AM	Mar 29, 2018 9:20 AM	Apr 07, 2018 2:56 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163347  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453234	1ST FLOOR CLASSROOM 108A	Mar 26, 2018 9:30 AM	Mar 29, 2018 9:25 AM	Apr 07, 2018 1:41 AM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163349  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525886	1ST FLOOR CLASSROOM 106A	Mar 26, 2018 3:30 AM	Mar 29, 2018 9:25 AM	Apr 07, 2018 1:52 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163351  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525773	1ST FLOOR CLASSROOM 105A	Mar 26, 2018 9:31 AM	Mar 29, 2018 9:25 AM	Apr 07, 2018 2:02 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163354  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525987	1ST FLOOR CLASSROOM 101A	Mar 26, 2018 9:25 AM	Mar 29, 2018 9:35 AM	Apr 07, 2018 2:13 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163357  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337181	1ST FLOOR CLASSROOM 102A	Mar 26, 2018 9:30 AM	Mar 29, 2018 9:35 AM	Apr 07, 2018 12:58 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163359  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525901	1ST FLOOR CLASSROOM 103A	Mar 26, 2018 9:30 AM	Mar 29, 2018 9:30 AM	Apr 07, 2018 1:09 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163361  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453098	1ST FLOOR CLASSROOM 104A	Mar 26, 2018 9:35 AM	Mar 29, 2018 9:30 AM	Apr 07, 2018 1:19 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163363  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525799	BASEMENT OFFICE #100	Mar 26, 2018 9:28 AM	Mar 29, 2018 9:35 AM	Apr 07, 2018 1:30 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163364  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453317	2ND FLOOR CLASSROOM 213B	Mar 26, 2018 8:30 AM	Mar 29, 2018 8:55 AM	Apr 07, 2018 12:15 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163365  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525733	2ND FLOOR CLASSROOM 214B	Mar 26, 2018 8:35 AM	Mar 29, 2018 8:55 AM	Apr 07, 2018 12:26 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163366  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525845	2ND FLOOR CLASSROOM 215B	Mar 26, 2018 8:35 AM	Mar 29, 2018 9:00 AM	Apr 07, 2018 12:37 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163370  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607974	2ND FLOOR CLASSROOM 216B	Mar 26, 2018 8:40 AM	Mar 29, 2018 9:00 AM	Apr 07, 2018 12:47 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163371  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525885	2ND FLOOR CLASSROOM 209B	Mar 26, 2018 8:15 AM	Mar 29, 2018 8:45 AM	Apr 06, 2018 11:33 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163372  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525967	2ND FLOOR CLASSROOM 210B	Mar 26, 2018 8:20 AM	Mar 29, 2018 8:50 AM	Apr 06, 2018 11:16 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163374  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607937	2ND FLOOR CLASSROOM 211B	Mar 26, 2018 8:20 AM	Mar 29, 2018 8:50 AM	Apr 06, 2018 11:26 PM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163377  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525927	2ND FLOOR CLASSROOM 212B	Mar 26, 2018 8:25 AM	Mar 29, 2018 8:50 AM	Apr 07, 2018 7:42 PM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163380  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4568756	2ND FLOOR CLASSROOM 204A	Mar 26, 2018 8:00 AM	Mar 29, 2018 8:40 AM	Apr 07, 2018 7:31 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163382  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525860	2ND FLOOR CLASSROOM 205A	Mar 26, 2018 8:00 AM	Mar 29, 2018 8:40 AM	Apr 07, 2018 7:21 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163385  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453294	2ND FLOOR CLASSROOM 206A	Mar 26, 2018 8:05 AM	Mar 29, 2018 8:40 AM	Apr 07, 2018 7:10 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163387  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD NE  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453124	2ND FLOOR CLASSROOM 208A	Mar 26, 2018 8:10 AM	Mar 29, 2018 8:45 AM	Apr 07, 2018 6:59 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163389  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453094	2ND FLOOR CLASSROOM 200C	Mar 26, 2018 7:45 AM	Mar 29, 2018 8:30 AM	Apr 07, 2018 6:48 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163391  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525787	2ND FLOOR CLASSROOM 200B OFFICE	Mar 26, 2018 7:45 AM	Mar 29, 2018 8:30 AM	Apr 07, 2018 6:38 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163393  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607991	2ND FLOOR CLASSROOM 201A	Mar 26, 2018 7:50 AM	Mar 29, 2018 8:35 AM	Apr 07, 2018 6:27 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163396  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525792	2ND FLOOR CLASSROOM 202/203A	Mar 26, 2018 7:55 AM	Mar 29, 2018 8:35 AM	Apr 08, 2018 5:15 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163399  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525699	2ND FLOOR CLASSROOM 8C SCIENCE LAB	Mar 26, 2018 7:30 AM	Mar 29, 2018 8:20 AM	Apr 08, 2018 5:25 AM	1.1 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163400  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453301	2ND FLOOR CLASSROOM 7C SCIENCE LAB	Mar 26, 2018 7:30 AM	Mar 29, 2018 8:25 AM	Apr 08, 2018 5:35 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



TEST ID NUMBER: 1163404  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MOLALLA HIGH SCHOOL  
357 FRANCIS ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453284	2ND FLOOR CLASSROOM 61 SCIENCE LAB	Mar 26, 2018 7:35 AM	Mar 29, 2018 8:25 AM	Apr 08, 2018 5:45 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**LAB ANALYSIS FOR:**

**MOLALLA RIVER MIDDLE SCHOOL  
318 Leroy Ave  
Molalla, OR 97038**



**TEST ID NUMBER:** 1163155  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525951	2ND FLOOR STAFF LOUNGE	Mar 26, 2018 10:41 AM	Mar 29, 2018 10:42 AM	Apr 07, 2018 11:19 AM	0.7 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163159  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525776	2ND FLOOR CLASSROOM 24 COMP LAB	Mar 26, 2018 10:52 AM	Mar 29, 2018 10:49 AM	Apr 07, 2018 11:08 AM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163162  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525817	2ND FLOOR CLASSROOM 25	Mar 26, 2018 10:55 AM	Mar 29, 2018 10:51 AM	Apr 07, 2018 10:58 AM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163165  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453215	2ND FLOOR CLASSROOM 26	Mar 26, 2018 10:58 AM	Mar 29, 2018 10:53 AM	Apr 07, 2018 7:15 AM	1.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163169  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525676	2ND FLOOR CLASSROOM 3	Mar 26, 2018 11:10 AM	Mar 29, 2018 11:02 AM	Apr 07, 2018 7:05 AM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163172  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453018	2ND FLOOR CLASSROOM 30	Mar 26, 2018 11:10 AM	Mar 29, 2018 11:02 AM	Apr 07, 2018 6:55 AM	0.9 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163173  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607987	2ND FLOOR CLASSROOM	Mar 26, 2018 11:15 AM	Mar 29, 2018 11:05 AM	Apr 07, 2018 6:45 AM	1.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163175  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453145	2ND FLOOR CLASSROOM 32	Mar 26, 2018 11:18 AM	Mar 29, 2018 11:06 AM	Apr 07, 2018 6:35 AM	1.1 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163176  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607970	2ND FLOOR CLASSROOM 39	Mar 26, 2018 11:47 AM	Mar 29, 2018 11:14 AM	Apr 07, 2018 6:25 AM	0.8 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163180  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525835	2ND FLOOR CLASSROOM 38	Mar 26, 2018 11:52 AM	Mar 29, 2018 11:16 AM	Apr 07, 2018 7:25 AM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163183  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607928	2ND FLOOR CLASSROOM 43	Mar 26, 2018 11:57 AM	Mar 29, 2018 11:18 AM	Apr 07, 2018 3:26 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163185  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLLALA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453304	2ND FLOOR CLASSROOM 41	Mar 26, 2018 12:00 PM	Mar 29, 2018 11:20 AM	Apr 07, 2018 3:15 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163187  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525846	2ND FLOOR CLASSROOM 35	Mar 26, 2018 11:21 AM	Mar 29, 2018 11:08 AM	Apr 07, 2018 3:05 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163188  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453241	2ND FLOOR CLASSROOM 34	Mar 26, 2018 11:40 AM	Mar 29, 2018 11:10 AM	Apr 07, 2018 2:54 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163190  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607942	2ND FLOOR CLASSROOM 37	Mar 26, 2018 11:43 AM	Mar 29, 2018 11:12 AM	Apr 07, 2018 2:43 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163192  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453039	2ND FLOOR CLASSROOM 36	Mar 26, 2018 11:45 AM	Mar 29, 2018 11:11 AM	Apr 07, 2018 7:55 AM	1.1 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163194  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453178	2ND FLOOR CLASSROOM	Mar 26, 2018 11:00 AM	Mar 29, 2018 10:54 AM	Apr 07, 2018 7:45 AM	1.1 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163197  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525853	2ND FLOOR SUPPORT 284	Mar 26, 2018 11:03 AM	Mar 29, 2018 10:56 AM	Apr 07, 2018 2:33 AM	1.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163200  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525941	2ND FLOOR CLASSROOM	Mar 26, 2018 11:01 AM	Mar 29, 2018 10:58 AM	Apr 07, 2018 2:22 AM	0.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163203  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453259	2ND FLOOR CLASSROOM 28	Mar 26, 2018 11:07 AM	Mar 29, 2018 11:45 AM	Apr 07, 2018 2:11 AM	1.1 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163208  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453290	2ND FLOOR CLASSROOM 23	Mar 26, 2018 12:05 PM	Mar 29, 2018 10:47 AM	Apr 07, 2018 2:00 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163213  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607996	2ND FLOOR GYM	Mar 26, 2018 11:06 AM	Mar 29, 2018 11:02 AM	Apr 07, 2018 1:50 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163215  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525887	2ND FLOOR GYM	Mar 26, 2018 11:07 AM	Mar 29, 2018 11:02 AM	Apr 07, 2018 5:48 AM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163221  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607984	BASEMENT BOYS LOCKER	Mar 26, 2018 11:15 AM	Mar 29, 2018 11:04 AM	Apr 07, 2018 1:17 AM	0.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163225  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525894	1ST FLOOR OFFICE	Mar 26, 2018 10:58 AM	Mar 29, 2018 10:49 AM	Apr 07, 2018 1:07 AM	1.1 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163228  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453230	1ST FLOOR OFFICE	Mar 26, 2018 10:58 AM	Mar 29, 2018 10:49 AM	Apr 07, 2018 12:56 AM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163239  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525759	2ND FLOOR GYM	Mar 26, 2018 11:18 AM	Mar 29, 2018 11:13 AM	Apr 07, 2018 12:24 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163241  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525734	2ND FLOOR GYM	Mar 26, 2018 11:15 AM	Mar 29, 2018 11:11 AM	Apr 07, 2018 12:13 AM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163245  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607931	BASEMENT GYM	Mar 26, 2018 11:22 AM	Mar 29, 2018 11:10 AM	Apr 07, 2018 12:02 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163247  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525680	2ND FLOOR GYM	Mar 26, 2018 11:25 AM	Mar 29, 2018 11:12 AM	Apr 06, 2018 11:52 PM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163251  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525781	1ST FLOOR OFFICE	Mar 26, 2018 10:45 AM	Mar 29, 2018 11:35 AM	Apr 06, 2018 11:41 PM	0.9 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163254  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525869	2ND FLOOR CONFERENCE ROOM	Mar 26, 2018 10:50 AM	Mar 29, 2018 11:35 AM	Apr 07, 2018 3:48 AM	1.0 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163257  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525942	2ND FLOOR COPY ROOM	Mar 26, 2018 10:53 AM	Mar 29, 2018 11:36 AM	Apr 07, 2018 3:37 AM	1.0 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163258  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525968	BASEMENT OTHER	Mar 26, 2018 10:54 AM	Mar 29, 2018 10:47 AM	Apr 07, 2018 5:26 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163260  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97002

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453120	2ND FLOOR CLASSROOM	Mar 26, 2018 11:40 AM	Mar 29, 2018 11:16 AM	Apr 07, 2018 5:15 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163263  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453183	2ND FLOOR MUSIC	Mar 26, 2018 11:45 AM	Mar 29, 2018 11:16 AM	Apr 07, 2018 5:05 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163266  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607946	BASEMENT OCCUPATIONAL THERAPY	Mar 26, 2018 11:45 AM	Mar 29, 2018 11:15 AM	Apr 07, 2018 4:54 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163309  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525731	2ND FLOOR CLASSROOM	Mar 26, 2018 10:55 AM	Mar 29, 2018 10:45 AM	Apr 07, 2018 3:15 AM	0.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163311  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337193	2ND FLOOR CLASSROOM	Mar 26, 2018 10:55 AM	Mar 29, 2018 10:45 AM	Apr 07, 2018 3:26 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163314  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533391	2ND FLOOR OFFICE	Mar 26, 2018 11:00 AM	Mar 29, 2018 10:50 AM	Apr 07, 2018 1:26 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163316  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533385	2ND FLOOR CLASSROOM	Mar 26, 2018 11:25 AM	Mar 29, 2018 10:50 AM	Apr 07, 2018 1:37 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163320  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533105	2ND FLOOR CLASSROOM	Mar 26, 2018 11:35 AM	Mar 29, 2018 10:55 AM	Apr 07, 2018 2:53 AM	1.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163321  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525768	2ND FLOOR CLASSROOM	Mar 26, 2018 11:40 AM	Mar 29, 2018 10:55 AM	Apr 07, 2018 3:04 AM	1.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163323  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4452996	BASEMENT CLASSROOM	Mar 26, 2018 11:45 AM	Mar 29, 2018 11:00 AM	Apr 07, 2018 8:35 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163326  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525936	BASEMENT CLASSROOM	Mar 26, 2018 11:45 AM	Mar 29, 2018 11:00 AM	Apr 07, 2018 7:45 AM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163329  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525839	2ND FLOOR OFFICE	Mar 26, 2018 11:50 AM	Mar 29, 2018 11:00 AM	Apr 07, 2018 8:46 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163332  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525700	2ND FLOOR CLASSROOM	Mar 26, 2018 11:50 AM	Mar 29, 2018 11:00 AM	Apr 07, 2018 8:57 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163334  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533379	2ND FLOOR CLASSROOM	Mar 26, 2018 11:55 AM	Mar 29, 2018 11:15 AM	Apr 07, 2018 9:07 PM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163336  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525875	2ND FLOOR OFFICE	Mar 26, 2018 11:55 AM	Mar 29, 2018 11:05 AM	Apr 07, 2018 7:53 PM	2.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163340  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525797	2ND FLOOR OFFICE	Mar 26, 2018 12:00 PM	Mar 29, 2018 11:05 AM	Apr 07, 2018 8:03 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163342  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337197	2ND FLOOR CAFETERIA	Mar 26, 2018 12:00 PM	Mar 29, 2018 11:05 AM	Apr 07, 2018 8:14 PM	1.9 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163344  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337186	2ND FLOOR CAFETERIA	Mar 26, 2018 12:00 PM	Mar 29, 2018 11:05 AM	Apr 07, 2018 8:25 PM	1.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163348  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525890	2ND FLOOR OTHER	Mar 26, 2018 12:05 PM	Mar 29, 2018 11:15 AM	Apr 07, 2018 11:37 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163350  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525945	2ND FLOOR OTHER	Mar 26, 2018 12:05 PM	Mar 29, 2018 11:10 AM	Apr 08, 2018 6:26 AM	0.4 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163353  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453251	2ND FLOOR OFFICE	Mar 26, 2018 12:10 PM	Mar 29, 2018 11:10 AM	Apr 08, 2018 6:36 AM	1.0 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163356  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525719	2ND FLOOR CLASSROOM	Mar 26, 2018 11:10 AM	Mar 29, 2018 10:50 AM	Apr 08, 2018 6:46 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163358  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525858	2ND FLOOR CLASSROOM	Mar 26, 2018 11:10 AM	Mar 29, 2018 10:50 AM	Apr 07, 2018 12:05 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163360  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525971	2ND FLOOR CLASSROOM	Mar 26, 2018 11:15 AM	Mar 29, 2018 10:55 AM	Apr 06, 2018 11:54 PM	0.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163362  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MOLALLA RIVER MIDDLE SCHOOL  
318 LEROY ST  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525960	2ND FLOOR CLASSROOM	Mar 26, 2018 11:20 AM	Mar 29, 2018 10:55 AM	Apr 06, 2018 11:43 PM	0.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**LAB ANALYSIS FOR:**

**MULINO ELEMENTARY  
26660 OR-213  
Mulino, OR 97042**



**TEST ID NUMBER:** 1163402  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525810	2ND FLOOR OFFICE	Mar 27, 2018 1:28 PM	Mar 29, 2018 5:42 PM	Apr 07, 2018 10:22 PM	0.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163406  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525992	2ND FLOOR OTHER	Mar 27, 2018 1:28 PM	Mar 29, 2018 5:42 PM	Apr 07, 2018 10:11 PM	1.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



TEST ID NUMBER: 1163410  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
452675	BASEMENT GYM	Mar 27, 2018 1:29 PM	Mar 29, 2018 5:45 PM	Apr 07, 2018 10:01 PM	1.9 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163414  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607951	2ND FLOOR CLASSROOM	Mar 27, 2018 1:42 PM	Mar 29, 2018 5:50 PM	Apr 07, 2018 9:50 PM	2.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163417  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

### TEST LOCATION

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453318	2ND FLOOR CAFETERIA	Mar 27, 2018 1:45 PM	Mar 29, 2018 5:51 PM	Apr 07, 2018 9:39 PM	1.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163421  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525993	2ND FLOOR OFFICE	Mar 27, 2018 1:50 PM	Mar 29, 2018 6:00 PM	Apr 07, 2018 9:29 PM	2.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163423  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525921	2ND FLOOR CLASSROOM	Mar 27, 2018 1:52 PM	Mar 29, 2018 6:03 PM	Apr 07, 2018 9:18 PM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163429  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453289	2ND FLOOR OFFICE	Mar 27, 2018 1:45 PM	Mar 29, 2018 5:52 PM	Apr 08, 2018 4:29 AM	1.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163443  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453320	2ND FLOOR CLASSROOM	Mar 27, 2018 2:02 PM	Mar 29, 2018 5:25 PM	Apr 07, 2018 11:47 PM	0.2 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163446  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453303	2ND FLOOR CLASSROOM	Mar 27, 2018 2:04 PM	Mar 29, 2018 5:25 PM	Apr 09, 2018 10:06 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163451  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525905	BASEMENT CLASSROOM	Mar 27, 2018 2:06 PM	Mar 29, 2018 5:26 PM	Apr 09, 2018 10:17 AM	0.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163454  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

### TEST LOCATION

MULINO ELEMENTARY  
11981 FARGO ROAD NORTHEAST,  
MARION COUNTY  
AURORA, OR 97002

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337196	2ND FLOOR OTHER	Mar 27, 2018 1:55 PM	Mar 29, 2018 5:30 PM	Apr 09, 2018 10:28 AM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163459  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453252	2ND FLOOR CLASSROOM	Mar 27, 2018 2:00 PM	Mar 29, 2018 5:32 PM	Apr 09, 2018 11:47 AM	1.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163460  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525856	2ND FLOOR CLASSROOM	Mar 27, 2018 2:00 PM	Mar 29, 2018 5:32 PM	Apr 09, 2018 11:57 AM	1.0 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163467  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525666	2ND FLOOR CLASSROOM	Mar 27, 2018 2:10 PM	Mar 29, 2018 5:48 PM	Apr 09, 2018 12:17 PM	1.5 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163425  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE-AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453187	2ND FLOOR CLASSROOM	Mar 27, 2018 1:40 PM	Mar 29, 2018 5:50 PM	Apr 08, 2018 4:19 AM	0.7 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163265  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525723	2ND FLOOR OFFICE	Mar 27, 2018 1:45 PM	Mar 29, 2018 3:58 PM	Apr 07, 2018 3:47 AM	2.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163270  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525897	2ND FLOOR OFFICE	Mar 27, 2018 1:45 PM	Mar 29, 2018 5:55 PM	Apr 07, 2018 12:20 AM	2.3 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163275  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525934	BASEMENT	Mar 27, 2018 1:47 PM	Mar 29, 2018 5:58 PM	Apr 07, 2018 12:31 AM	2.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163280  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453330	BASEMENT OFFICE	Mar 27, 2018 1:50 PM	Mar 29, 2018 5:58 PM	Apr 07, 2018 12:42 AM	2.8 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163284  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525896	BASEMENT OFFICE	Mar 27, 2018 1:50 PM	Mar 29, 2018 5:58 PM	Apr 07, 2018 12:52 AM	2.8 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163288  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525868	2ND FLOOR OFFICE	Mar 27, 2018 1:52 PM	Mar 29, 2018 5:58 PM	Apr 06, 2018 11:37 PM	2.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163294  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525796	2ND FLOOR CLASSROOM	Mar 27, 2018 2:05 PM	Mar 29, 2018 5:59 PM	Apr 06, 2018 11:48 PM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163297  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607945	BASEMENT	Mar 27, 2018 1:55 PM	Mar 29, 2018 6:50 PM	Apr 06, 2018 11:59 PM	0.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163300  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525958	2ND FLOOR CLASSROOM	Mar 27, 2018 2:00 PM	Mar 29, 2018 5:30 PM	Apr 07, 2018 12:09 AM	0.8 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163302  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525721	2ND FLOOR GYM	Mar 27, 2018 2:01 PM	Mar 29, 2018 5:30 PM	Apr 06, 2018 10:54 PM	0.7 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV



**TEST ID NUMBER:** 1163306  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453249	2ND FLOOR OFFICE	Mar 27, 2018 2:02 PM	Mar 29, 2018 6:35 PM	Apr 06, 2018 11:05 PM	0.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163379  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525969	2ND FLOOR OFFICE	Mar 27, 2018 1:27 PM	Mar 29, 2018 5:42 PM	Apr 07, 2018 10:33 PM	1.2 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163464  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525714	2ND FLOOR OFFICE	Mar 27, 2018 2:05 PM	Mar 29, 2018 4:32 PM	Apr 09, 2018 12:07 PM	3.9 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163434  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY  
26660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607923	2ND FLOOR CLASSROOM	Mar 27, 2018 1:50 PM	Mar 29, 2018 6:02 PM	Apr 07, 2018 11:05 PM	8.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163438  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**  
MULINO ELEMENTARY  
2660 HWY 213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453097	2ND FLOOR CLASSROOM	Mar 27, 2018 1:50 PM	Mar 29, 2018 6:02 PM	Apr 07, 2018 11:26 PM	5.3 pCi/L

### THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

#### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**LAB ANALYSIS FOR:**

**RUAL DELL  
10500 OR-211  
Molalla, OR 97038**



TEST ID NUMBER: 1163271  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEMENTARY  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337178	2ND FLOOR CLASSROOM 5	Mar 27, 2018 10:10 AM	Mar 29, 2018 2:24 PM	Apr 07, 2018 4:43 AM	0.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1163276  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEMENTARY  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525687	2ND FLOOR OFFICE E	Mar 27, 2018 4:15 AM	Mar 29, 2018 2:24 PM	Apr 07, 2018 4:33 AM	0.6 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163279  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEMENTARY  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525996	2ND FLOOR LIBRARY A	Mar 27, 2018 10:20 AM	Mar 29, 2018 1:22 PM	Apr 07, 2018 4:22 AM	0.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

TEST ID NUMBER: 1163281  
DATE RECEIVED: 04/06/2018  
REPORT DATE: 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEMENTARY  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607989	2ND FLOOR A LIBRARY LEFT SIDE	Mar 27, 2018 10:20 AM	Mar 29, 2018 1:21 PM	Apr 07, 2018 4:11 AM	0.7 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163283  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEMENTARY  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533398	2ND FLOOR GYM	Mar 27, 2018 1:03 AM	Mar 29, 2018 2:29 AM	Apr 07, 2018 4:01 AM	2.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163287  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

### TEST LOCATION

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEMENTARY  
10500 N HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525703	2ND FLOOR GYM	Mar 27, 2018 5:07 AM	Mar 29, 2018 2:29 PM	Apr 07, 2018 3:50 AM	2.5 pCi/L

### **THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163291  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525883	2ND FLOOR GYM	Mar 27, 2018 10:08 AM	Mar 29, 2018 2:29 PM	Apr 07, 2018 1:39 AM	1.9 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163293  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607992	2ND FLOOR GYM	Mar 27, 2018 10:10 AM	Mar 29, 2018 2:29 PM	Apr 07, 2018 1:28 AM	2.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163296  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453300	2ND FLOOR CLASSROOM 1	Mar 27, 2018 10:00 AM	Mar 29, 2018 1:20 PM	Apr 07, 2018 7:34 AM	0.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163298  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453266	2ND FLOOR CLASSROOM 2	Mar 27, 2018 10:00 AM	Mar 29, 2018 1:23 PM	Apr 07, 2018 7:24 AM	0.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163299  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525698	2ND FLOOR CLASSROOM 3	Mar 27, 2018 10:05 AM	Mar 29, 2018 2:23 PM	Apr 07, 2018 7:13 AM	0.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163301  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4337188	2ND FLOOR CLASSROOM 4	Mar 27, 2018 10:05 AM	Mar 29, 2018 2:24 PM	Apr 07, 2018 7:03 AM	1.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163303  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4533395	2ND FLOOR ROOM B	Mar 27, 2018 10:07 AM	Mar 29, 2018 1:25 PM	Apr 07, 2018 6:52 AM	2.0 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163304  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525876	2ND FLOOR CLASSROOM 7	Mar 27, 2018 10:08 AM	Mar 29, 2018 1:26 PM	Apr 07, 2018 6:41 AM	1.2 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1163307  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525774	2ND FLOOR CLASSROOM 4	Mar 27, 2018 10:09 AM	Mar 29, 2018 1:26 PM	Apr 07, 2018 6:30 AM	1.6 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163308  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607927	2ND FLOOR CLASSROOM 9	Mar 27, 2018 10:12 AM	Mar 29, 2018 1:27 PM	Apr 07, 2018 6:20 AM	0.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163312  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525977	2ND FLOOR CLASSROOM 10	Mar 27, 2018 10:19 AM	Mar 29, 2018 1:28 PM	Apr 07, 2018 6:09 AM	0.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



James E. McDonnell IV

**TEST ID NUMBER:** 1163318  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525706	2ND FLOOR GYM	Mar 27, 2018 10:15 AM	Mar 29, 2018 2:29 PM	Apr 07, 2018 5:47 AM	3.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



**TEST ID NUMBER:** 1163315  
**DATE RECEIVED:** 04/06/2018  
**REPORT DATE:** 04/13/2018

**TEST LOCATION**

ENVIRONMENTAL INSPECTION SERVICES - AURO  
11981 FARGO RD  
AURORA, OR 97002

RUAL DELL ELEM  
10500 S HWY 211  
CLACKAMAS COUNTY  
MOLALLA, OR 97038

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525889	2ND FLOOR MRS JAVIER OFFICE	Mar 27, 2018 10:15 AM	Mar 29, 2018 1:28 PM	Apr 07, 2018 5:58 AM	7.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**Mollala River School District Radon Retest  
Rural Dell - 10500 OR-211  
Mulino Elementary School - 26660 OR-213  
Clarkes Elementary School - 19100 S. Windy City Road**

**EIS Job No. 2018046**

**Prepared For:**

**Attn: Tony Tiano, Facilities Supervisor  
The Molalla River School District  
412 Swiegle Avenue  
Molalla, Oregon 97038**

**Prepared By:**

**Charles A. Spear, Environmental Professional  
Environmental Inspection Services  
11981 Fargo Road  
Aurora, Oregon 97002  
Cell No. 503-680-6398  
Email: [charles\\_a\\_spear@yahoo.com](mailto:charles_a_spear@yahoo.com)**

  
\_\_\_\_\_

**June 19, 2018**



**EIS**  
**ENVIRONMENTAL INSPECTION SERVICES**



June 19, 2018  
EIS Job No. 2018046

Attn: Tony Tiano, Facilities Supervisor  
The Molalla River School District  
412 Swiegle Avenue  
Molalla, Oregon 97038

Reference: Radon Retests at the Molalla River School district facilities known as Rural Dell at 10500 OR-211, Mulino Elementary School at 26660 OR-213, and Clarkes Elementary School at 19100 S. Windy City Road

Dear Mr. Tiano,

An initial radon test of all the Molalla River School District school facilities was conducted between March 26 and March 29, 2018. Low radon levels were measured at the Molalla High School, Molalla Elementary School, and Molalla River Middle Schools. Elevated radon levels were measured at very limited functional areas at the Mulino Elementary School, Clarkes Elementary School, and the Rural Dell School.

The initial March, 2018 radon assessment elevated radon concentrations are listed as follows;

<u>SCHOOL</u>	<u>ROOM SPACE</u>	<u>RADON TEST RESULT</u>
Mulino Elementary School	Class # 22	Vial # 4453097 - 5.3 pCi/L
Mulino Elementary school	Class # 21	Vial # 4607923 - 8.6 pCi/L
Rural Dell School	Javier class	Vial #4525889 - 5.3 pCi/L
Clarkes Elementary	Room 12 office	Vial # 4525772 - 4.5 pCi/L
Clarkes Elementary	Room 12 main	Vial # 4525972 - 4.0 pCi/L
Clarkes Elementary	Health Room	vial # 4525708 - 4.2 pCi/L

The elevated radon measurements prompted a radon retest of the selected aforementioned school measurement areas in June, 2018. Two (2) passive samplers were placed into each of the designated retest areas for quality control purposes resulting in a total of twelve (12) samplers placed during the June retest episode. The elevated radon levels exceeding the action limit of 4 pCi/l analytically confirmed in the June samplers are listed as follows;

<u>SCHOOL</u>	<u>ROOM SPACE</u>	<u>RADON TEST RESULT</u>
Mulino Elementary school	Class # 21	Vial # 4525851 - 7.9 pCi/L
Mulino Elementary school	Class # 21	Vial # 4607972 - 14.4 pCi/L
Rural Dell School	Javier class	Vial # 4453306 - 6.3 pCi/L
Rural Dell School	Javier class	Vial # 4607961 - 5.5 pCi/L
Clarkes Elementary	Room 12 main	Vial # 4525859 - 4.5 pCi/L
Clarkes Elementary	Room 12 main	Vial # 4525673 - 5.3 pCi/L
Clarkes Elementary	Health Room	vial # 4525985 - 5.0 pCi/L
Clarkes Elementary	Health Room	vial # 4453193 - 4.8 pCi/L

#### **RESULT SUMMARY**

The radon retest elevated measurements are slightly elevated. The highest initial and retest measurements were noted at the Mulino elementary School Class # 21.

The initial and retest samplers are known as passive samplers. The selected radon test devices are activated charcoal adsorption devices (AC) with charcoal treated to increase the ability to adsorb radon gas. The passive nature of the activated charcoal allows continual adsorption and desorption of radon. The adsorbed radon undergoes radioactive decay and is typically measured between two to seven days. AC devices are inexpensive, no power is required, and accurate. The AC detectors do require laboratory analysis and are sensitive to humidity.

#### **RADON DESCRIPTION**

Radon is described as a naturally occurring colorless, tasteless and radioactive gas. Radon is also considered a Group A known human carcinogen. Radon travels through the soil and any openings in floor surfaces.

### **RADON INFLUENCES**

The elevated levels of radon in a building is dependent on the following factors

- (1.0) - The concentration of radium in the soil or underlying geology;
- (2.0) - The ease of radon transport into a building due to such factors as soil permeability; pathways, and openings in the building;
- (3.0) - Air differentials such as "stack effect" of warm air displaced by cooler air.
- (4.0) - HVAC air transport in a building
- (5/0) - Ventilation of the building.

### **RADON DESCRIPTION**

Radon eventually decays into radioactive decay particle products which exert energy known as ionizing energy which may be trapped in the lungs. The trapped ionizing energy may disrupt cellular DNA and damage the cancer suppressant genes. The decay particles further release radiation.

### **RADON RISK**

Prolonged exposure to radon concentrations increases the risk of lung cancer. Not everyone who breathes radon or radon decay products may develop lung cancer. The risk of lung cancer from radon exposure is dependent on several factors to include the actual concentration of radon, the duration of radon exposure, and genetic and health disposition. The risk of radon induced lung cancer does increase dramatically in smokers.

## RADON MEASUREMENTS

Radon is measured in curies. A curie is described as the amount of radioactivity released from one gram of radium. A picocurie is the standard measurement of radon. A single picocurie is one trillionth of a curie. Radon is actually measured and reported in picocuries per liter of air (pCi/L). The USEPA initial radon studies were conducted in schools in 1988. Radon levels were noted in schools in every part of the country. The National Radon Survey noted 19.3% of all schools have at least one frequently occupied room with radon levels above the USEPA action level of 4.0 pCi/L. This finding also noted that over 70,000 school rooms are impacted by radon.


## RECOMMENDATIONS

The USEPA, OHA Oregon Radon Awareness Program, and numerous non-governmental groups recommend that the school district take action to include radon level in those rooms where the average of the initial and followup short term kit results in test results of 4.0 pCi/l or greater. It is recommended that the school adjust the building's HVAC system and conduct long term retests during the summer break in the three elevated retest areas known as Mulino Elementary School, the Rural Dell School, and the Clarkes Elementary School.

Radon concentrations do fluctuate over time and are influenced by various physical conditions such as temperature, pressure changes; functional space ventilation changes; ground surface changes; and seasonal changes. The short term radon testing is a helpful snapshot of radon concentrations during test episodes and is helpful in focusing subsequent radon testing in large and diverse school systems. Environmental Inspection Services recommends the application of long term testing in the elevated three diverse radon areas. The continued analytical verification of elevated radon concentrations after HVAC adjustments and long term monitoring procedures would prompt an EIS recommendation for radon mitigation methods.

Thank you for this opportunity to be of service. If there are any questions feel free to contact me at (503) 680-6398.

Respectfully,

  
Charles A. Spear  
Environmental Professional

TEST ID NUMBER: 1177393  
 DATE RECEIVED: 06/15/2018  
 REPORT DATE: 06/18/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
 11981 FARGO ROAD NORTHEAST,  
 AURORA, OR 97002

**TEST LOCATION**  
 MULINO ELEMENTARY SCHOOL  
 26660 OR-213  
 CLACKAMAS COUNTY  
 MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525851	2ND FLOOR GYM-CLASS 21	Jun 08, 2018 10:10 AM	Jun 11, 2018 7:15 AM	Jun 16, 2018 5:41 AM	7.9 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.** Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS  
 NRPP CERT# 104126RT  
 NRSB CERT # 6SS0035



PRO-LAB NRSB # ARL0028  
 PRO-LAB NEHA ID # 101461AL

James E. McDonnell IV

TEST ID NUMBER: 1177394  
DATE RECEIVED: 06/15/2018  
REPORT DATE: 06/18/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY SCHOOL  
26660 OR-213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4607972	2ND FLOOR GYM-CLASS 21	Jun 08, 2018 10:10 AM	Jun 11, 2018 7:15 AM	Jun 16, 2018 6:24 AM	14.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS  
NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL



TEST ID NUMBER: 1177396  
DATE RECEIVED: 06/15/2018  
REPORT DATE: 06/18/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

MULINO ELEMENTARY SCHOOL  
26660 OR-213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453291	2ND FLOOR GYM-CLASS 22	Jun 08, 2018 10:10 AM	Jun 11, 2018 7:18 AM	Jun 16, 2018 4:37 AM	1.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1177397  
DATE RECEIVED: 06/15/2018  
REPORT DATE: 06/18/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

TEST LOCATION  
MULINO ELEMENTARY SCHOOL  
26660 OR-213  
CLACKAMAS COUNTY  
MULINO, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525770	2ND FLOOR GYM-CLASS 22	Jun 08, 2018 10:10 AM	Jun 11, 2018 7:18 AM	Jun 16, 2018 4:26 AM	1.4 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.** Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

### LIMITATIONS OF DATA AND PRODUCT LIABILITY

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1177401  
DATE RECEIVED: 06/15/2018  
REPORT DATE: 06/18/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

CLARKES ELEMENTARY SCHOOL  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525985	1ST FLOOR OFFICE-HEALTH	Jun 08, 2018 10:47 AM	Jun 11, 2018 7:38 AM	Jun 16, 2018 5:09 AM	5.0 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**


**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1177403  
DATE RECEIVED: 06/15/2018  
REPORT DATE: 06/18/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

CLARKES ELEMENTARY SCHOOL  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4453193	BASEMENT OFFICE-HEALTH	Jun 08, 2018 10:47 AM	Jun 11, 2018 7:38 AM	Jun 16, 2018 6:14 AM	4.8 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1177406  
DATE RECEIVED: 06/15/2018  
REPORT DATE: 06/18/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

CLARKES ELEMENTARY SCHOOL  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525859	2ND FLOOR OFFICE-CLARKES MAIN OFFICE	Jun 08, 2018 10:49 AM	Jun 11, 2018 7:38 AM	Jun 16, 2018 4:58 AM	4.5 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.** Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1177390  
DATE RECEIVED: 06/15/2018  
REPORT DATE: 06/18/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002

**TEST LOCATION**

CLARKES ELEMENTARY SCHOOL  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525948	2ND FLOOR GYM- CLASS 12	Jun 08, 2018 10:55 AM	Jun 11, 2018 7:52 AM	Jun 16, 2018 5:52 AM	1.5 pCi/L
4525786	2ND FLOOR GYM- CLASS 12	Jun 08, 2018 10:55 AM	Jun 11, 2018 7:52 AM	Jun 16, 2018 6:03 AM	2.0 pCi/L

**AVERAGE RADON LEVEL (average result of two tests) : 1.8 pCi/L**

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

**TEST ID NUMBER:** 1177407  
**DATE RECEIVED:** 06/15/2018  
**REPORT DATE:** 06/18/2018ENVIRONMENTAL INSPECTION SERVICE, INC.  
11981 FARGO ROAD NORTHEAST,  
AURORA, OR 97002**TEST LOCATION**CLARKES ELEMENTARY SCHOOL  
19100 S WINDY CITY RD  
CLACKAMAS COUNTY  
MOLALLA, OR 97042

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

**HERE ARE YOUR TEST RESULTS**

<u>VIAL #</u>	<u>ROOM TESTED</u>	<u>DATE OPENED</u>	<u>DATE CAPPED</u>	<u>DATE ANALYZED</u>	<u>RADON LEVEL</u>
4525673	2ND FLOOR OFFICE-CLARKES MAIN OFFICE	Jun 08, 2018 10:50 AM	Jun 11, 2018 7:38 AM	Jun 16, 2018 4:48 AM	5.3 pCi/L

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS

NRPP CERT# 104126RT  
NRSB CERT # 6SS0035

James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
PRO-LAB NEHA ID # 101461AL

TEST ID NUMBER: 1177386  
 DATE RECEIVED: 06/15/2018  
 REPORT DATE: 06/19/2018

ENVIRONMENTAL INSPECTION SERVICE, INC.  
 11981 FARGO ROAD NORTHEAST,  
 AURORA, OR 97002

**TEST LOCATION**  
 PEREZ  
 10500 S HWY 211  
 CLACKAMAS COUNTY  
 MOLALLA, OR 97002

This is a confidential report of the radon samples that were submitted to our laboratory for measurements of radon-222 levels. The results represent the amount of radon that was present in the air during the time of sampling. The radon is measured in our laboratory using the liquid scintillation method (EPA 402-R-92-004). This report will not be released to anyone without your permission except as required by individual state laws and guidelines.

## HERE ARE YOUR TEST RESULTS

VIAL #	ROOM TESTED	DATE OPENED	DATE CAPPED	DATE ANALYZED	RADON LEVEL
4453306	BASEMENT MRS JAVIER	Jun 08, 2018 9:57 AM	Jun 11, 2018 6:47 AM	Jun 16, 2018 11:06 AM	6.3 pCi/L
4607961	BASEMENT MRS JAVIER	Jun 08, 2018 9:57 AM	Jun 11, 2018 6:47 AM	Jun 16, 2018 11:17 AM	5.5 pCi/L

**AVERAGE RADON LEVEL (average result of two tests) : 5.9 pCi/L**

**THE EPA RECOMMENDS THAT YOU FIX YOUR HOME IF THE RADON LEVEL IS 4 PICOCURIES (PCi/L) OR HIGHER.**

Please read the EPA Citizen's Guide to Radon at [www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html). Residents of New Jersey should read "Radon Testing and Mitigation: The Basics" at <http://njradon.org/download/mitbas.pdf>. Radon levels less than 4 pCi/L still pose a risk. You may want to take additional measurements because radon levels can vary with the seasons. You may also want to consider doing a long term test to determine the average radon concentrations over a longer period of time. If the radon level is 4.0 pCi/L or higher you should perform either a long-term test or a second short-term test. If the radon level is higher than 10 pCi/L you should perform a second short-term test immediately. **If you would like to learn how to lower your radon levels, or have other questions, please contact your state radon office at (971) 673-0490.**

**LIMITATIONS OF DATA AND PRODUCT LIABILITY**

PRO-LAB expressly disclaims any and all liability for any special, incidental, or consequential damages resulting directly or indirectly from the improper use of or improper interpretation of the radon product or its results. Any delays in receipt of the test sample by PRO-LAB shall be the sole responsibility of the purchaser and their legal remedy shall be limited to recourse with their chosen carrier. Additionally, PRO-LAB shall not be responsible for the improper placement of the test canister nor shall PRO-LAB be liable for results derived directly or indirectly from the improper placement of said test canister. PRO-LAB, its agents, its retailers, its distributors, and the manufacturers' sole liability are limited to the cost for the replacement of the test canister itself only.



Malissa Sears, RMS  
 NRPP CERT# 104126RT  
 NRSB CERT # 6SS0035



James E. McDonnell IV

PRO-LAB NRSB # ARL0028  
 PRO-LAB NEHA ID # 101461AL