



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 07/14/2016

Received: 06/29/2016

Sampled By: Frederic Dettwyler

Work Order: 6181014

**C** Molalla River School District  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**  
Project # : N/A  
PWSID # : 41 90529

Sampling Location: MRSD

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6181014-01</b>	<b>Sample Name:</b> Mulino Kitchen Sink <b>Sampled:</b> 6/28/16 14:10		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	07/11/16 16:33
<b>6181014-02</b>	<b>Sample Name:</b> MES Rm 15 <b>Sampled:</b> 6/28/16 14:00		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	6.6	ppb	2.0	20 ppb	07/11/16 16:33
<b>181014-03</b>	<b>Sample Name:</b> MES Rm 16 <b>Sampled:</b> 6/28/16 14:01		<b>Matrix:</b> Water				
†Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	07/11/16 16:33

**ND** = None detected at the MRL      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is an action level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray  
Laboratory Director



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/24/2016  
Received: 06/15/2016  
Sampled By:  
Work Order: 6167025

**C** **Molalla River School District**  
**L** Attn: -  
**I** PO Box 188  
**E** Molalla OR, 97037  
**N** Phone: (503) 829-2359  
**T**

**Project:**  
Project # : N/A  
PWSID # :

Sampling Location:

### Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6167025-01</b>	<b>Sample Name:</b> Mulino Fountain Hall by Lib. <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-02</b>	<b>Sample Name:</b> Mulino Fountain Rm 8 <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-03</b>	<b>Sample Name:</b> Mulino Kitchen <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-04</b>	<b>Sample Name:</b> Mulino So. Blid. Breezway <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-05</b>	<b>Sample Name:</b> MES Lobby Fountain <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-06</b>	<b>Sample Name:</b> MES Rm 16 Fountain <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-07</b>	<b>Sample Name:</b> MES Kitchen <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-08</b>	<b>Sample Name:</b> MES Cafe. fountain <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-09</b>	<b>Sample Name:</b> MES Rm 14 fountain <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
<b>6167025-10</b>	<b>Sample Name:</b> MES Rm 4 fountain <b>Sampled:</b> 6/15/16 0:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53