



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/24/2016
Received: 06/15/2016
Sampled By:
Work Order: 6167025

C Molalla River School District
L Attn: -
I PO Box 188
E Molalla OR, 97037
N Phone: (503) 829-2359
T

Project:
Project # : N/A
PWSID # :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6167025-11	Sample Name: Molalla Middle 6th Grade DF Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-12	Sample Name: Molalla Middle D.F. Hall by Rm 26 Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-13	Sample Name: Molalla Middle Kitchen Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-14	Sample Name: Molalla Middle Cafe. DF Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-15	Sample Name: Land Lab fountain Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-16	Sample Name: Molalla H. School Kitchen Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-17	Sample Name: Molalla H. School commons DF. Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-18	Sample Name: Molalla H. School Capasso D.F. Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53
6167025-19	Sample Name: Molalla H. School New Wing by Elev. D.F. Sampled: 6/15/16 0:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/23/16 16:53

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.